ARBOR BASE SERIES

COMMERCIAL

Water Source/Geothermal Heat Pump

- R-410A Refrigerant
- Commercial 0.75-6 Ton

Installation Information

Water Piping Connections

Hot Water Connections

Electrical

Startup Procedures

Troubleshooting

Preventive Maintenance










Table of Contents

Model Nomenclature	4
General Installation Information	5
Dimensional Data	6-9
Installing Horizontal Units	10
Hanger Bracket Locations	
Duct System and Water Piping	12
Water Quality	13
Condensate Drain	13
System Cleaning and Flushing	14
Open Loop Ground Water Systems	15
Freeze Detection	16
Electrical Connections	16
Electrical Data	17-18
Blower Performance Data	19-22
5-Speed ECM Constant Torque Motors	23
Wiring Schematics	24-29
Controls - Aurora Base Control	30-33
Controls - FX10 (optional)	34-39
Unit Startup	40
Operating Parameters and Operating Limits	41
Pressure Drop	42
Compressor and Thermistor Resistance	43
Refrigerant Circuit Guideline	43
Heat of Extraction/Rejection Data	44
Reference Calculations and Legend	45
Troubleshooting	46
Startup/Troubleshooting Form	47-48
Preventive Maintenance	49
Replacement Procedures	49
Service Parts	50-51
Revision Guide	53

Model Nomenclature



Note: Phase Guard Only Available on 208-230/60/3, 460/60/3, and 575/60/3 50VA Transformer with Aurora and 75VA Transformer with FX10





General Installation Information

Safety Considerations



WARNING: Before performing service or maintenance operations on a system, turn off main power switches to the indoor unit. If applicable, turn off the accessory heater power switch. Electrical shock could cause personal injury.

Installing and servicing heating and air conditioning equipment can be hazardous due to system pressure and electrical components. Only trained and qualified service personnel should install, repair or service heating and air conditioning equipment. Untrained personnel can perform the basic maintenance functions of cleaning coils and cleaning and replacing filters. All other operations should be performed by trained service personnel. When working on heating and air conditioning equipment, observe precautions in the literature, tags and labels attached to the unit and other safety precautions that may apply.

Follow all safety codes. Wear safety glasses and work gloves. Use a quenching cloth for brazing operations and have a fire extinguisher available.

Moving and Storage


Move units in the normal "up" orientation. Horizontal units may be moved and stored per the information on the packaging. Do not stack more than three units in total height. Vertical units may be stored one upon another to a maximum height of two units. Do not attempt to move units while stacked. When the equipment is received, all items should be carefully checked against the bill of lading to be sure all crates and cartons have been received. Examine units for shipping damage, removing the units from the packaging if necessary. Units in question should also be internally inspected. If any damage is noted, the carrier should make the proper notation on the delivery receipt, acknowledging the damage.

Unit Location


Locate the unit in an indoor area that allows for easy removal of the filter and access panels. Location should have enough space for service personnel to perform maintenance or repair. Provide sufficient room to make water, electrical and duct connection(s). If the unit is located in a confined space, such as a closet, provisions must be made for return air to freely enter the space by means of a louvered door, etc. Any access panel screws that would be difficult to remove after the unit is installed should be removed prior to setting the unit. On horizontal units, allow adequate room below the unit for a condensate drain trap and do not locate the unit above supply piping. Care should be taken when units are located in unconditioned spaces to prevent damage from frozen water lines and excessive heat that could damage electrical components.

Installing Vertical Units

Vertical units are available in left or right air return configurations. Top flow vertical units should be mounted level on a vibration absorbing pad slightly larger than the base to provide isolation between the unit and the floor.



Vertical Dimensional Data



NOTE: * Water connections protrude approximately 1.5 in. from cabinet.

Vertical Dimensional Data cont.

						Water Co	nnections		Elec	trical Knock	outs	
		c	verall Cabin	et		water Co	nnections		6	7	8	
Vertica					1 2 5		Loop	J	K	L		
Model	s [Α	В	С	D	E	Н	Соор	1/2 in. cond	1/2 in. cond	1 in. cond	M
		Width	Depth	Height*	In	Out	Cond- ensate	Water FPT	Low Voltage	Low Voltage	Power Supply	Filter Rack Width
006-012	in.	19.2	19.2	24.2	2.6	5.6	8.8	1/2 in.	7.4	3.4	5.4	2.2
000-012	cm.	48.8	48.8	61.5	6.6	14.2	22.4	12.7 mm	18.8	8.6	13.7	5.6
015-018	in.	22.5	22.2	30.2	2.6	7.6	10.8	3/4 in.	9.4	5.4	7.4	2.2
015-016	cm.	57.2	56.4	76.7	6.6	19.3	27.4	19.1 mm	23.9	13.7	18.8	5.6
024-030	in.	22.5	22.2	36.2	2.6	7.6	10.8	3/4 in.	9.4	5.4	7.4	2.2
024-030	cm.	57.2	56.4	91.9	6.6	19.3	27.4	19.1 mm	23.9	13.7	18.8	5.6
036	in.	22.5	26.2	40.2	2.6	7.6	10.8	3/4 in.	10.1	6.1	8.1	2.2
036	cm.	57.2	66.5	102.1	6.6	19.3	27.4	19.1 mm	25.7	15.5	20.6	5.6
042-048	in.	22.5	26.2	44.2	2.6	7.6	10.8	3/4 in.	10.1	6.1	8.1	2.2
042-046	cm.	57.2	66.5	112.3	6.6	19.3	27.4	19.1 mm	25.7	15.5	20.6	5.6
060	in.	25.5	31.2	44.2	2.6	7.6	10.8	1 in.	10.1	6.1	8.1	2.2
000	cm.	64.8	79.2	112.3	6.6	19.3	27.4	25.4 mm	25.7	15.5	20.6	5.6
070	in.	25.5	31.2	48.2	2.6	7.6	10.8	1 in.	10.1	6.1	8.1	2.2
070	cm.	64.8	79.2	122.4	6.6	19.3	27.4	25.4 mm	25.7	15.5	20.6	5.6

Vertical				harge Connec nge installed (±			**Return Connection using deluxe filter rack (±0.10 in)				
Models	3	N	Р	Q	R	S	Т	U	V	W	
		Supply Width	Supply Depth					Return Depth	Return Height		
000 040	in.	10.0	10.0	4.6	4.4	7.8	2.4	14.3	10.1	2.0	
006-012	cm.	25.4	25.4	11.7	11.2	19.8	6.1	36.3	25.7	5.1	
045 040	in.	14.0	14.0	4.1	4.3	7.7	2.1	18.1	14.0	2.0	
015-018	cm.	35.6	35.6	10.4	10.9	19.6	5.3	46.0	35.6	5.1	
004.000	in.	14.0	14.0	4.1	4.3	7.7	2.1	18.1	20.0	2.0	
024-030	cm.	35.6	35.6	10.4	10.9	19.6	5.3	46.0	50.8	5.1	
	in.	14.0	14.0	6.1	4.5	7.7	2.1	22.1	22.1	2.0	
036	cm.	35.6	35.6	15.5	11.4	19.6	5.3	56.1	56.1	5.1	
040.040	in.	18.0	18.0	4.1	3.9	3.9	2.1	22.1	26.1	2.0	
042-048	cm.	45.7	45.7	10.4	9.9	9.9	5.3	56.1	66.3	5.1	
	in.	18.0	18.0	6.6	4.6	6.3	1.6	28.1	26.0	2.0	
060	cm.	45.7	45.7	16.8	11.7	16.0	4.1	71.4	66.0	5.1	
070	in.	18.0	18.0	6.6	4.6	6.3	1.6	28.1	30.0	2.0	
070	cm.	45.7	45.7	16.8	11.7	16.0	4.1	71.4	76.2	5.1	
			alue socket and is				•			09/26	


Condensate is 3/4 in. PVC female glue socket and is switchable from side to front.

Vertical Disconnect

When using disconnect, do not use dimension L from the standard vertical dimensional data. Use dimension LL from the vertical disconnect dimensional data.

Vertical Models	LL
015-018	15.8 [40.1]
024-030	18.8 [47.8]
036	15.3 [38.9]
042-048	13.8 [35.1]
060	14.3 [36.3]
070	14.3 [36.3]

Dimensions in inches [cm]




^{*} Discharge flange is field installed and extends 1 in. (25.4 mm) from top of cabinet.

^{**} Vertical units shipped with standard 2 in. (field adjustable to 1 in.) open application filter rail extending 2.2 in. from the unit and is not suitable for duct connection. For ductable return connection applications, order the 2 in. (field adjustable to 1 in.) duct collar/filter rack which extends to 3.25 in. from the unit and is suitable for duct connections.

^{*} Models 006-012 - Externally Mounted Disconnect

Horizontal Dimensional Data



NOTE: * Water connections protrude approximately 1.5 in. from cabinet.

Horizontal Dimensional Data cont.

			Overall Cabine			Water Co	nnections		Electrical Knockouts		
Horizont	al [Overall Cabine	•	1	2	3	Loop	J	K	
Models		Α	A B	С	D	E	Н	СООР	1/2 in. cond	1 in. cond	
		Width	Depth	Height*	In	Out	Condensate	Water FPT	Low Voltage	Power Supply	
006-012**	in.	19.2	35.0	12.1	1.8	4.8	3.6	1/2 in.	7.4	7.5	
000-012	cm.	48.8	88.9	30.7	4.6	12.2	9.1	12.70 mm	18.8	19.1	
015-018	in.	22.5	35.0	17.2	1.8	6.8	0.8	3/4 in.	7.1	7.1	
015-016	cm.	57.2	88.9	43.7	4.6	17.3	2.0	19.05 mm	18.0	18.0	
024-030	in.	22.5	42.0	17.2	1.8	6.8	0.8	3/4 in.	7.1	7.1	
024-030	cm.	57.2	106.7	43.7	4.6	17.3	2.0	19.05 mm	18.0	18.0	
036	in.	22.5	42.0	19.2	1.8	6.8	0.8	3/4 in.	9.2	7.1	
036	cm.	57.2	106.7	48.8	4.6	17.3	2.0	19.05 mm	23.4	18.0	
042-048	in.	22.5	45.0	19.2	1.8	6.8	0.8	3/4 in.	9.2	7.1	
042-046	cm.	57.2	114.3	48.8	4.6	17.3	2.0	19.05 mm	23.4	18.0	
060	in.	25.5	48.0	21.2	1.8	6.8	0.8	1 in.	9.2	9.1	
000	cm.	64.8	121.9	53.8	4.6	17.3	2.0	25.4 mm	23.4	23.1	
070	in.	25.5	53.0	21.2	1.8	6.8	0.8	1 in.	9.2	9.1	
0/0	cm.	64.8	134.6	53.8	4.6	17.3	2.0	25.4 mm	23.4	23.1	

Horizont	al			Connection talled (±0.10 in)		usi	Return Co		in)	PVC Size
Models		L	M	N	Р	Q	R	S	Т	Х
			Supply Width	Supply Depth		Return Depth	Return Height			
006-012**	in.	2.3	8.0	10.0	2.7	22.5	9.4	2.4	1.4	1/2 in.
000-012	cm.	5.8	20.3	25.4	6.9	57.2	23.9	6.1	3.6	1.3
015-018	in.	5.7	10.5	9.4	4.9	16.4	14.5	2.0	1.4	3/4 in.
013-016	cm.	14.5	26.7	23.9	12.4	41.7	36.8	5.1	3.6	1.9
024 020	in.	5.7	10.5	9.4	4.9	23.4	14.5	2.0	1.4	3/4 in.
024-030	cm.	14.5	26.7	23.9	12.4	59.4	36.8	5.1	3.6	1.9
036	in.	6.7	10.5	9.4	4.9	27.4	16.5	2.0	1.4	3/4 in.
036	cm.	17.0	26.7	23.9	12.4	69.6	41.9	5.1	3.6	1.9
042-048	in.	4.2	13.6	13.2	2.4	30.4	16.5	2.0	1.5	3/4 in.
042-046	cm.	10.7	34.5	33.5	6.1	77.2	41.9	5.1	3.8	1.9
060	in.	4.8	13.6	13.2	4.6	35.4	18.7	2.3	1.3	3/4 in.
060	cm.	12.2	34.5	33.5	11.7	89.9	47.5	5.8	3.3	1.9
070	in.	4.8	13.6	13.2	4.6	40.4	18.5	2.3	1.4	3/4 in.
070	cm.	12.2	34.5	33.5	11.7	102.6	47.0	5.8	3.6	1.9

Horizontal units shipped with standard 2 in. (field adjustable to 1 in.) open application filter rail extending 2.2 in. from the unit and is not suitable for duct connection. For ductable return connection applications, order the 2 in. (field adjustable to 1 in.) duct collar/filter rack which extends to 3.25 in. from the unit and is suitable for duct connections.


09/26/12

Horizontal Disconnect

When using disconnect, do not use dimension K from the standard horizontal dimensional data. Use dimension KK from the horizontal disconnect dimensional data.

Horizontal Models	KK
015-018	8.2 [20.8]
024-030	8.2 [20.8]
036	9.2 [23.4]
042-048	9.2 [23.4]
060	11.2 [28.4]
070	10.2 [25.9]

Dimensions in inches [cm]



^{**} H006-012 offers a lifted drain pan that allows the trap to be installed without additional ceiling height required.

^{*} Models 006-012 - Externally Mounted Disconnect

Installing Horizontal Units

Installing Horizontal Units

Horizontal units are available with side or end discharge and may be easily field converted by flipping the blower discharge panel. Horizontal units are normally suspended from a ceiling by four 3/8 in. diameter threaded rods. The rods are usually attached to the unit by hanger bracket kits furnished with each unit. Lay out the threaded rods per the dimensions below. Assemble the hangers to the unit as shown. Securely tighten the brackets to the unit using the weld nuts located on the underside of the bottom panel. When attaching the hanger rods to the bracket, a double nut is required since vibration could loosen a single nut.


NOTE: The unit should be pitched approximately 1/4 in. towards the drain in both directions to facilitate the removal of condensate.

Use only the bolts provided in the kit to attach hanger brackets. The use of longer bolts could damage internal parts. Some applications require the installation of horizontal units on an attic floor. In this case, the unit should be set in a full size secondary drain pan on top of a vibration absorbing pad. The secondary drain pan prevents possible condensate overflow or water leakage damage to the ceiling. The secondary drain pan is usually placed on a plywood base isolated from the ceiling joists by additional layers of vibration absorbing material. Insulate supply plenum and use at least one 90° elbow and flexible duct collar to reduce noise.




CAUTION: Do not use rods smaller than 3/8 in. diameter since they may not be strong enough to support the unit. The rods must be securely anchored to the ceiling.

Horizontal Unit Mounting



Hanger Bracket Locations



Hanger Dimensions

Model		Hanger Kit	Unit I	Hanger Dimens	sions
Wode		Part Number	Α	В	С
006-012	in.	99S500A04	35.8	21.8	18.1
000-012	cm.	995500A04	90.9	55.4	46.0
015-018	in.	99S500A04	35.8	25.1	21.4
015-016	cm.	995500A04	90.9	63.8	54.4
004.000	in.	99S500A04	42.8	25.1	21.4
024-030	cm.	995500A04	108.6	63.8	54.4
036	in.	99S500A04	42.8	25.1	21.4
036	cm.	995500A04	108.7	63.8	54.4
042-048	in.	99S500A04	45.8	25.1	21.4
042-046	cm.	993300A04	116.3	63.8	54.4
060	in.	99S500A04	48.8	28.1	24.4
000	cm.	993300A04	124.0	71.4	62.0
070	in.	99S500A04	53.8	28.1	24.4
070	cm.	993300A04	136.7	71.4	62.0

09/26/12

Weight Distribution

		Vertical	Horizontal	Horizo	ntal Weig	ght Distri	bution	
Mod	lel	Shipping	Shipping	Fre	ont	Back		
		Weight	Weight	D	E	F G		
006-	lb.	111	112	44	21	19	28	
012	kg	50	51	20	10	9	12	
015-	lb.	171	176	67	32	32	45	
018	kg	78	80	30	15	15	20	
024	lb.	245	242	85	47	45	65	
024	kg	111	110	39	21	20	29	
030	lb.	245	242	85	47	45	65	
	kg	111	110	39	21	20	29	
036	lb.	267	265	95	60	50	60	
036	kg	121	120	43	27	23	27	
042	lb.	305	310	105	68	60	77	
042	kg	138	141	48	31	27	35	
048	lb.	305	310	105	68	60	77	
046	kg	138	141	48	31	27	35	
060	lb.	344	350	115	77	68	90	
000	kg	156	159	52	35	31	41	
070	lb.	357	378	130	80	73	95	
070	kg	162	171	59	36	33	43	
							10/03/12	

10/03/12

Duct System

An air outlet collar is provided on vertical top flow units and all horizontal units to facilitate a duct connection. A flexible connector is recommended for discharge and return air duct connections on metal duct systems. Uninsulated duct should be insulated with a minimum of 1-inch duct insulation. Application of the unit to uninsulated ductwork in an unconditioned space is not recommended as the unit's performance will be adversely affected.

If the unit is connected to existing ductwork, check the duct system to ensure that it has the capacity to accommodate the air required for the unit application. If the duct is too small, as in the replacement of heating only systems, larger ductwork should be installed. All existing ductwork should be checked for leaks and repaired if necessary.

The duct system should be sized to handle the design airflow quietly and efficiently. To maximize sound attenuation of the unit blower, the supply and return plenums should include an internal duct liner of fiberglass or constructed of ductboard for the first few feet. On systems employing a sheet metal duct system, canvas connectors should be used between the unit and the ductwork. If air noise or excessive airflow is a problem, the blower speed can be changed.

Water Piping

The proper water flow must be provided to each unit whenever the unit operates. To assure proper flow, use pressure/temperature ports to determine the flow rate. These ports should be located at the supply and return water connections on the unit. The proper flow rate cannot be accurately set without measuring the water pressure drop through the refrigerant-to-water heat exchanger.

All source water connections on commercial units are fittings that accept a male pipe thread (MPT). Insert the connectors by hand, then tighten the fitting with a wrench to provide a leakproof joint. When connecting to an open loop (groundwater) system, thread any copper MPT fitting into the connector and tighten in the same manner as described above.

Water Quality

In ground water situations where scaling could be heavy or where biological growth such as iron bacteria will be present, a closed loop system is recommended. The heat exchanger coils in ground water systems may, over a period of time, lose heat exchange capabilities due to a buildup of mineral deposits inside. These can be cleaned, but only by a qualified service mechanic, as special solutions and pumping equipment are required. Hot water generator coils can likewise become scaled and possibly plugged.

In areas with extremely hard water, the owner should be informed that the heat exchanger may require occasional flushing. Failure to adhere to the guidelines in the water quality table could result in loss of warranty.

Units with cupronickel heat exchangers are recommended for open loop applications due to the increased resistance to build-up and corrosion, along with reduced wear caused by acid cleaning.

Material		Copper	90/10 Cupronickel	316 Stainless Steel	
pH	Acidity/Alkalinity	7 - 9	7 - 9	7 - 9	
Scaling	Calcium and Magnesium Carbonate	(Total Hardness) less than 350 ppm	(Total Hardness) less than 350 ppm	(Total Hardness) less than 350 ppm	
	Hydrogen Sulfide	Less than 0.5 ppm (rotten egg smell appears at 0.5 ppm)	10 - 50 ppm	Less than 1 ppm	
	Sulfates	Less than 125 ppm	Less than 125 ppm	Less than 200 ppm	
	Chlorine	Less than 0.5 ppm	Less than 0.5 ppm	Less than 0.5 ppm	
	Chlorides	Less than 20 ppm	Less than 125 ppm	Less than 300 ppm	
	Carbon Dioxide	Less than 50 ppm	10 - 50 ppm	10 - 50 ppm	
Corrosion	Ammonia	Less than 2 ppm	Less than 2 ppm	Less than 20 ppm	
	Ammonia Chloride	Less than 0.5 ppm	Less than 0.5 ppm	Less than 0.5 ppm	
	Ammonia Nitrate	Less than 0.5 ppm	Less than 0.5 ppm	Less than 0.5 ppm	
[Ammonia Hydroxide	Less than 0.5 ppm	Less than 0.5 ppm	Less than 0.5 ppm	
[Ammonia Sulfate	Less than 0.5 ppm	Less than 0.5 ppm	Less than 0.5 ppm	
	Total Dissolved Solids (TDS)	Less than 1000 ppm	1000 - 1500 ppm	1000 - 1500 ppm	
	LSI Index	+0.5 to -0.5	+0.5 to -0.5	+0.5 to -0.5	
Iron Fouling	Iron, FE ² + (Ferrous) Bacterial Iron Potential	< 0.2 ppm	< 0.2 ppm	< 0.2 ppm	
(Biological Growth)	Iron Oxide	Less than 1 ppm, above this level deposition will occur	Less than 1 ppm, above this level deposition will occur	Less than 1 ppm, above this level deposition will occur	
Francism	Suspended Solids	Less than 10 ppm and filtered for max. of 600 micron size	Less than 10 ppm and filtered for max. of 600 micron size	Less than 10 ppm and filtered for max. of 600 micron size	
Erosion	Threshold Velocity (Fresh Water)	< 6 ft/sec	< 6 ft/sec	< 6 ft/sec	

NOTES: Grains = ppm divided by 17 mg/L is equivalent to ppm

2/22/12


Condensate Drain

On vertical units, the internal condensate drain assembly consists of a drain tube which is connected to the drain pan, a 3/4 in. PVC female adapter and a flexible connecting hose. The female adapter may exit either the front or the side of the cabinet. The adapter should be glued to the field-installed PVC condensate piping. On vertical units, a condensate hose is inside all cabinets as a trapping loop; therefore, an external trap is not necessary.


On horizontal units, a PVC stub or stainless steel tube is provided for condensate drain piping connection. An external trap is required (see below). If a vent is necessary, an open stand pipe may be applied to a tee in the field-installed condensate piping.

NOTE: All units equipped with electronic condensate overflow protection.

Horizontal Drain Connection (Composite Drain Pan)



Unit Pitch for Drain




System Cleaning and Flushing

Cleaning and Flushing

Prior to start up of any heat pump, the water circulating system must be cleaned and flushed of all dirt and debris.

If the system is equipped with water shutoff valves, the supply and return runouts must be connected together at each unit location (This will prevent the introduction of dirt into the unit, see Flushing with Water Shutoff Valve Equipped Systems illustration). The system should be filled at the water make-up connection with all air vents open. After filling, vents should be closed.

Flushing with Water Shutoff Valve Equipped Systems



The contractor should start the main circulator with the pressure reducing valve makeup open. Vents should be checked in sequence to bleed off any trapped air and to verify circulation through all components of the system.

As water circulates through the system, the contractor should check and repair any leaks found in the piping system. Drain(s) at the lowest point(s) in the system should be opened for initial flush and blowdown, making sure water fill valves are set at the same rate. Check the pressure gauge at the pump suction and manually adjust the make-up water valve to hold the same positive pressure both before and after opening the drain valves. Flushing should continue for at least two hours, or longer if required, until drain water is clean and clear.

The supplemental heater and/or circulator pump, if used, should be shut off. All drains and vents should be opened to completely drain the system. Short-circuited supply and return runouts should now be connected to the unit supply and return connections.

Refill the system with clean water. Test the system water for acidity and treat as required to leave the water slightly alkaline (pH 7.5 to 8.5). The specified percentage of antifreeze may also be added at this time. Use commercial grade antifreeze designed for HVAC systems only. Environol™ brand antifreeze is recommended.

Once the system has been filled with clean water and antifreeze (if used), precautions should be taken to protect the system from dirty water conditions. Dirty water will result in system-wide degradation of performance, and solids may clog valves, strainers, flow regulators, etc. Additionally, the heat exchanger may become clogged which reduces compressor service life and can cause premature unit failure.

In boiler/tower application, set the loop control panel set points to desired temperatures. Supply power to all motors and start the circulating pumps. After full flow has been established through all components including the heat rejector (regardless of season), air vented and loop temperatures stabilized, each of the units will be ready for check, test and start up and for air and water balancing.

Ground Source Loop System Checkout

Once piping is completed between the unit pumping system and ground loop, final purging and charging of the loop is needed. A high pressure pump is needed to achieve adequate flow velocity in the loop to purge air and dirt particles from the loop itself. Antifreeze solution is used in most areas to prevent freezing. Flush the system adequately to remove as much air as possible; then pressurize the loop to a static pressure of 40-50 PSI (summer) or 50-75 PSI (winter). This is normally adequate for good system operation. Loop static pressure may decrease soon after initial installation, due to pipe expansion and loop temperature change. Running the unit for at least 30 minutes after the system has been completely purged of air will allow for the "break-in" period. It may be necessary to adjust static loop pressure (by adding water) after the unit has run for the first time. Loop static pressure will also fluctuate with the seasons. Pressures will be higher in the winter months than during the cooling season. This fluctuation is normal and should be considered when charging the system initially.


Ensure the pump provides adequate flow through the unit by checking pressure drop across the heat exchanger.
Usually 2.25-3.0 gpm of flow per ton of cooling capacity is recommended in earth loop applications.

Open Loop Ground Water Systems

Typical open loop piping is shown below. Always maintain water pressure in the heat exchanger by placing water control valves at the outlet of the unit to prevent mineral precipitation. Use a closed, bladder-type expansion tank to minimize mineral formation due to air exposure. Insure proper water flow through the unit by checking pressure drop across the heat exchanger and comparing it to the figures in unit capacity data tables in the specification catalog. 1.5-2 gpm of flow per ton of cooling capacity is recommended in open loop applications. Due to only minor differences in flow rate from low to high, only one solenoid valve should be used. The valve should be sized for full flow.

Discharge water from the unit is not contaminated in any manner and can be disposed of in various ways, depending on local codes, i.e. recharge well, storm sewer, drain field, adjacent stream or pond, etc. Most local codes forbid the use of sanitary sewer for disposal. Consult your local building and zoning departments to assure compliance in your area.

Open System - Groundwater Application



Freeze Detection

For Aurora Base Control, set SW2-1, FP1, on the printed circuit board for applications using a closed loop antifreeze solution to 15°F [-9.4°C]. On applications using an open loop/ground water system (or closed loop no antifreeze), set this dip switch to 30°F [-1.1°C], the factory default setting. (Refer to the Dip Switch Field Selection table).

For FX10 board, the "red" wire must be removed from PB2-3 to change from 30°F [-1.1°C], the factory default setting, to 15°F [-9.4°C].

Electrical Connections

General

Be sure the available power is the same voltage and phase as that shown on the unit serial plate. Line and low voltage wiring must be done in accordance with local codes or the National Electric Code, whichever is applicable.

Power Connection

Connect the incoming line voltage wires to L1 and L2 of the contactor for single-phase unit. Consult the Electrical Data tables for correct fuse sizes.


208 Volt Operation

All Arbor Base Series 208/230 units are factory wired for 230 volt operation. For 208 volt operation, the red and blue transformer wires must be switched on terminal strip PS.




CAUTION: When installing a unit with a variable speed ECM blower motor in 460/60/3 voltage, a neutral wire is required to allow proper unit operation.

Aurora Base Control Box



FX10 Control Box



Electrical Data

PSC Motor

	Patrid	Valtana		Compressor		Blower	Total	Min	Max
Model	Rated Voltage	Voltage Min/Max	мсс	RLA	LRA	Motor FLA	Unit FLA	Circ Amp	Fuse/ HACR
	115/60/1	104/127	9.5	6.1	29.0	1.5	7.6	9.1	15
006	208-230/60/1	198/253	4.7	3.0	15.0	0.6	3.6	4.4	10/15
	265/60/1	238/292	4.2	2.7	11.0	0.6	3.3	4.0	10/15
	115/60/1	104/127	12.5	8.0	50.0	1.5	9.5	11.5	15
009	208-230/60/1	198/253	6.4	4.1	21.0	0.6	4.7	5.7	10/15
	265/60/1	238/292	6.7	4.3	22.0	0.6	4.9	6.0	10/15
	115/60/1	104/127	14.8	9.5	50.0	1.5	11.0	13.4	20
012	208-230/60/1	198/253	7.7	4.9	25.0	0.6	5.5	6.7	10/15
	265/60/1	238/292	70	4.5	22.0	0.6	5.1	6.2	10/15
	208-230/60/1	198/253	9.2	5.9	29.0	1.1	7.8	9.5	15
015	265/60/1	238/292	7.8	5.0	28.0	1.0	6.6	8.0	10/15
	208-230/60/1	198/253	10.4	6.7	33.5	1.1	7.8	9.5	15
018	265/60/1	238/292	8.7	5.6	28.0	1.0	6.6	8.0	10/15
	208-230/60/1	198/253	13.0	7.4	43.0	1.2	8.6	10.5	15
	265/60/1	238/292	12.6	6.7	46.0	1.1	7.8	9.5	15
024	208-230/60/3	187/253	13.0	5.9	63.0	1.2	7.1	8.6	10/15
	460/60/3	414/506	6.0	2.9	30.0	0.6	3.5	4.2	10/15
	208-230/60/1	198/253	17.5	9.4	54.0	1.5	10.9	13.3	20
	265/60/1	238/292	14.0	8.0	46.0	1.5	9.5	11.5	15
030	208-230/60/3	187/253	13.5	6.6	63.0	1.5	8.1	9.8	15
	460/60/3	414/506	6.4	3.2	30.0	1.0	4.2	5.0	10/15
	208-230/60/1	198/253	20.5	11.6	74.0	2.2	13.8	16.7	25
	265/60/1	238/292	17.7	9.9	67.0	1.1	11.0	13.5	20
036	208-230/60/3	187/253	13.5	7.4	68.0	2.2	9.6	11.5	15
	460/60/3	414/506	7.1	3.8	34.0	1.1	4.9	5.9	10/15
	208-230/60/1	198/253	25.0	13.0	88.0	3.5	16.5	19.8	30
	208-230/60/3	187/253	14.5	8.6	68.0	3.5	12.1	14.3	20
042	460/60/3	342/506	7.7	4.2	34.0	1.8	6.0	7.1	10/15
	575/60/3	517/633	6.0	3.5	28.0	1.4	4.9	5.8	10/15
	208-230/60/1	198/253	24.5	15.7	84.0	3.5	19.2	23.1	35
	208-230/60/3	187/253	17.5	11.0	88.0	3.5	14.5	17.3	25
048	460/60/3	342/506	8.0	5.6	44.0	1.8	7.4	8.8	10/15
	575/60/3	517/633	7.0	4.4	36.0	1.9	5.8	6.9	10/15
	208-230/60/1	198/253	33.0	21.1	105.0	5.9	27.0	32.3	50
	208-230/60/3	187/253	22.0	12.9	88.0	5.9	18.8	22.0	30
060	460/60/3	342/506	12.0	6.7	55.0	3.0	9.7	11.4	15
	575/60/3	517/633	7.5	5.1	36.0	1.9	7.0	8.3	10/15
	208-230/60/1	198/253	36.0	23.0	130.0	5.9	28.9	34.7	50
	208-230/60/1	187/253	24.6	14.3	110.0	5.9	20.2	23.8	35
070	460/60/3	342/506	11.5	7.1	55.0	3.0	10.1	11.9	15
					-		-		
	575/60/3	517/633	8.7	5.6	43.0	1.9	7.5	8.9	10/15

HACR circuit breaker in USA only

Electrical Data cont.

5-Speed ECM Motor

		Valtaria		Compressor		Blower	Total	Min	Max
Model	Rated Voltage	Voltage Min/Max	мсс	RLA	LRA	Motor FLA	Unit FLA	Circ Amp	Fuse/ HACR
015	208-230/60/1	198/253	9.2	5.9	29.0	4.1	10.0	11.5	15
015	265/60/1	238/292	7.8	5.0	28.0	3.6	8.6	9.8	10/15
018	208-230/60/1	198/253	10.4	6.7	33.5	4.1	10.8	12.5	15
010	265/60/1	238/292	8.7	5.6	28.0	3.6	9.2	10.6	10/15
	208-230/60/1	198/253	13.0	7.4	43.0	4.1	11.5	13.4	20
024	265/60/1	238/292	12.6	6.7	46.0	3.6	10.3	12.0	15
024	208-230/60/3	187/253	13.0	5.9	63.0	4.1	10.0	11.5	15
	460/60/3	414/506	6.0	2.9	30.0	2.1	5.0	5.7	10/15
	208-230/60/1	198/253	17.5	9.4	54.0	4.1	13.5	15.9	25
030	265/60/1	238/292	14.0	8.0	46.0	3.6	11.6	13.6	20
030	208-230/60/3	187/253	13.5	6.6	63.0	4.1	10.7	12.4	15
	460/60/3	414/506	6.4	3.2	30.0	2.1	5.3	6.1	10/15
	208-230/60/1	198/253	20.5	11.6	74.0	4.1	15.7	18.6	30
036	265/60/1	238/292	17.7	9.9	67.0	3.6	13.5	16.0	25
036	208-230/60/3	187/253	13.5	7.4	68.0	4.1	11.5	13.4	20
	460/60/3	414/506	7.1	3.8	34.0	2.1	5.9	6.9	10/15
	208-230/60/1	198/253	25.0	13.0	88.0	7.6	20.6	23.9	35
042	208-230/60/3	187/253	14.5	8.6	68.0	7.6	16.2	18.4	25
	460/60/3	414/506	7.7	4.2	34.0	4.0	8.2	9.3	10/15
	208-230/60/1	198/253	24.5	15.7	84.0	7.6	23.3	27.2	40
048	208-230/60/3	187/253	17.5	11.0	88.0	7.6	18.6	21.4	30
	460/60/3	414/506	8.0	5.6	44.0	4.0	9.6	11.0	15
	208-230/60/1	198/253	33.0	21.1	105.0	7.6	28.7	34.0	50
060	208-230/60/3	187/253	22.0	12.9	88.0	7.6	20.5	23.7	35
	460/60/3	414/506	12.0	6.7	55.0	4.0	10.7	12.4	15
	208-230/60/1	198/253	36.0	23.0	130.0	7.6	30.6	36.4	50
070	208-230/60/3	187/253	24.6	14.3	110.0	7.6	21.9	25.5	35
	460/60/3	414/506	11.5	7.1	55.0	4.0	11.1	12.9	20

HACR circuit breaker in USA only

Electrical Data cont.

Variable Speed ECM Motor

	Rated	Voltage Min/Max		Compressor		Blower	Total	Min	Max
Model	Voltage		мсс	RLA	LRA	Motor FLA	Unit FLA	Circ Amp	Fuse/ HACR
015	208-230/60/1	198/253	9.2	5.9	29.0	4.0	9.9	11.4	15
015	265/60/1	238/292	7.8	5.0	28.0	4.1	9.1	10.3	15
018	208-230/60/1	198/253	10.4	6.7	33.5	4.0	10.7	12.4	15
010	265/60/1	238/292	8.7	5.6	28.0	4.1	9.7	11.1	15
	208-230/60/1	198/253	13.0	7.4	43.0	4.0	11.4	13.3	20
024	265/60/1	238/292	12.6	6.7	46.0	4.1	10.8	12.5	20
024	208-230/60/3	187/253	13.0	5.9	63.0	4.0	9.9	11.4	15
	460/60/3	414/506	6.0	2.9	30.0	4.1	7.0	7.7	10/15
	208-230/60/1	198/253	17.5	9.4	54.0	4.0	13.4	15.8	25
030	265/60/1	238/292	14.0	8.0	46.0	4.1	12.1	14.1	20
	208-230/60/3	187/253	13.5	6.6	63.0	4.0	10.6	12.3	20
	460/60/3	414/506	6.4	3.2	30.0	4.1	7.3	8.1	10/15
	208-230/60/1	198/253	20.5	11.6	74.0	4.0	15.6	18.5	30
036	265/60/1	238/292	17.7	9.9	67.0	4.1	14.0	16.5	25
036	208-230/60/3	187/253	13.5	7.4	68.0	4.0	11.4	13.3	20
	460/60/3	414/506	7.1	3.8	34.0	4.1	7.9	8.9	15
	208-230/60/1	198/253	25.0	13.0	88.0	4.0	17.0	20.3	35
042	208-230/60/3	187/253	14.5	8.6	68.0	4.0	12.6	14.8	25
	460/60/3	414/506	7.7	4.2	34.0	4.1	8.3	9.4	15
	208-230/60/1	198/253	24.5	15.7	84.0	4.0	19.7	23.6	40
048	208-230/60/3	187/253	17.5	11.0	88.0	4.0	15.0	17.8	30
	460/60/3	414/506	8.0	5.6	44.0	4.1	9.7	11.1	15
	208-230/60/1	198/253	33.0	21.1	105.0	7.0	28.1	33.4	55
060	208-230/60/3	187/253	22.0	12.9	88.0	7.0	19.9	23.1	35
	460/60/3	414/506	12.0	6.7	55.0	6.9	13.6	15.3	25
	208-230/60/1	198/253	36.0	23.0	130.0	7.0	30.0	35.8	60
070	208-230/60/3	187/253	24.6	14.3	110.0	7.0	21.3	24.9	40
	460/60/3	414/506	11.5	7.1	55.0	6.9	14.0	15.8	25

HACR circuit breaker in USA only

10/03/12



CAUTION: When installing a unit with an variable speed ECM blower motor in 460/60/3 voltage, a neutral wire is required to allow proper unit operation.

Blower Performance Data

Standard PSC Motor

Madel	Blower	Blower	Motor					Α	irflow (cfm) at I	External	Static I	ressur	e (in. wg	j)				
Model	Spd	Size	HP	0	0.05	0.10	0.15	0.20	0.25	0.30	0.35	0.40	0.45	0.50	0.60	0.70	0.80	0.90	1.00
	Н			435	425	415	405	390	365	340	325	305	290	275	245	-	-	-	-
	МН		4/40	400	390	380	370	355	335	310	295	280	265	255	210	195	-	-	-
006	ML*	6 x 8	1/10	365	355	345	335	315	300	280	270	255	240	230	195	-	-	-	-
	L			320	305	295	280	260	250	235	225	210	195	180	150	135	-	-	-
	Н			435	423	415	405	390	370	340	325	305	290	275	245	-	-	-	-
009	МН		4/40	400	388	380	370	355	335	310	295	280	265	255	210	195	-	-	-
009	ML*	6 x 8	1/10	365	353	345	335	315	300	280	270	255	240	230	195	-	-	-	-
	L			320	305	295	280	260	250	235	225	210	195	180	150	135	-	-	-
	Н			435	423	415	405	390	370	340	325	305	290	275	245	-	-	-	-
040	МН	00	4/40	400	388	380	370	355	335	310	295	280	265	255	210	195	-	-	-
012	ML*	6 x 8	1/10	365	353	345	335	315	300	280	270	255	240	230	195	-	-	-	-
	L			320	305	295	280	260	250	235	225	210	195	180	150	135	-	-	-
	Н			795	775	755	735	715	690	670	600	530	490	455	395	-	-	-	-
015	М	9 x 7	1/6	725	710	695	675	660	640	620	560	495	465	435	375	-	-	-	-
	L	İ		620	610	600	590	575	550	525	490	455	395	340	290	-	-	-	-
	Н			795	775	755	735	715	690	670	600	530	490	455	395	-	-	-	-
018	М	9 x 7	1/6	725	710	695	675	660	640	620	560	495	465	435	375	-	-	-	-
	L	İ	İ	620	610	600	590	575	550	525	490	455	395	340	290	-	-	-	-
	Н			1035	1015	995	970	950	925	900	865	835	795	760	685	560	-	-	-
024	М	9 x 7	1/5	880	860	845	820	805	785	765	740	720	690	665	590	530	-	-	-
	L			810	790	775	755	740	725	705	675	650	620	595	510	-	-	-	-
	Н			1170	1145	1130	1110	1080	1050	1030	995	965	925	890	815	700	-	-	-
030	М	9 x 7	1/3	1040	1030	1020	1005	990	965	945	915	890	860	830	760	650	-	-	-
	L			825	820	815	810	805	795	790	775	765	735	705	655	-	-	-	-
	Н			1320	1295	1275	1240	1210	1185	1155	1120	1085	1045	1005	915	805	655	-	-
036	М	9 x 7	1/2	1180	1155	1140	1125	1100	1075	1055	1020	990	955	920	840	725	590	-	-
	L			1045	1035	1025	1015	1005	985	970	945	920	890	865	795	690	-	-	-
	Н			1530	1500	1475	1445	1425	1380	1340	1290	1240	1185	1130	810	715	630	-	-
042	М	10x10	1/2	1435	1415	1395	1370	1350	1325	1300	1265	1235	1180	1130	1040	755	640	-	-
	L			1160	1140	1130	1120	1100	1070	1050	1020	990	950	910	831	632	590	-	-
	Н			1845	1810	1775	1740	1705	1660	1615	1560	1510	1455	1405	1275	1080	-	-	-
048	М	10 x 10	1/2	1655	1620	1585	1555	1535	1500	1465	1415	1370	1330	1290	1170	970	-	-	-
	L			1325	1315	1310	1285	1265	1245	1220	1180	1140	1115	1090	990	-	-	-	-
	Н			2345	2320	2305	2285	2250	2205	2180	2135	2090	2060	2030	1945	1850	1740	1600	1465
060	М	11 x 10	1	2195	2170	2150	2125	2105	2075	2045	2005	1970	1940	1915	1845	1770	1630	1500	-
	L			2045	2030	2020	1995	1980	1950	1925	1890	1855	1825	1800	1750	1640	1535	1395	-
	Н			2505	2475	2450	2410	2385	2365	2340	2305	2275	2250	2230	2170	2070	1975	1880	1765
070	М	11 x 10	1	2290	2265	2250	2230	2200	2170	2150	2135	2125	2105	2085	2015	1950	1865	1785	1680
	L	L		2115	2100	2085	2060	2040	2020	2005	1990	1975	1950	1930	1875	1805	1720	1655	1510
	settings :	ara in Da	14															1	0/03/12

Factory settings are in Bold

Airflow values are with dry coil and standard filter


For wet coil performance first calculate the face velocity of the air coil (Face Velocity [fpm] = Airflow [cfm] / Face Area [sq ft]).

Then for velocities of 200 fpm reduce the static capability by 0.03 in. wg, 300 fpm by 0.08 in. wg, 400 fpm by 0.12 in. wg. and 500 fpm by 0.16 in. wg.

Setting Blower Speed - PSC



CAUTION: Disconnect all power before performing this operation.



^{*} Setting for 265V operation.

Blower Performance Data cont.


5-Speed ECM Motor

	Motor	Motor	Blower	Motor					Air	flow (c	m) at E	xterna	Static	Pressu	re (in.	vg)						
Model	Spd	Тар	Size	HP	0	0.05	0.10	0.15	0.20	0.25	0.30	0.35	0.40	0.45	0.50	0.60	0.70	0.80	0.90	1.00		
	High	5			915	895	880	865	850	830	815	805	795	775	750	730	695	640	-	-		
	Med High	4]		805	785	765	750	740	725	705	685	665	655	635	605	535	-	-	-		
015	Med	3	9 x 7	1/2	725	715	700	680	660	635	615	600	585	560	535	485	-	-	-	-		
	Med Low	2			695	675	650	630	610	590	575	550	525	490	455	-	-	-	-	-		
	Low	1			655	600	550	530	508	490	475	435	395	350	-	-	-	-	-	-		
	High	5			915	895	880	865	850	830	815	805	795	775	750	730	695	640	-	-		
	Med High	4]		805	785	765	750	740	725	705	685	665	655	635	605	535	-	-	-		
018	Med	3	9 x 7	1/2	725	715	700	680	660	635	615	600	585	560	535	485	-	-	-	-		
	Med Low	2]		695	675	650	630	610	590	575	550	525	490	455	-	-	-	-	-		
	Low	1			655	600	550	530	508	490	475	435	395	350	-	-	-	-	-	-		
	High	5			1000	983	965	950	935	923	910	900	890	873	855	800	825		-	-		
	Med High	4			905	888	870	860	850	833	815	805	795	775	755	740	705	-	-	-		
024	Med	3	9 x 7	1/2	855	838	820	800	780	773	765	745	725	715	705	670	580	-	-	-		
	Med Low	2]		790	773	755	743	730	710	690	675	660	643	625	570	-	-	-	-		
	Low	1			615	600	585	565	545	523	500	468	435	408	380	-	-	-	-	-		
	High	5			1315	1293	1270	1243	1215	1183	1150	1120	1090	1055	1020	930	845	-	-	-		
	Med High	4			1145	1130	1115	1105	1095	1080	1065	1053	1040	1013	985	905	820	-	-	-		
030	Med	3	9 x 7	1/2	1020	1008	995	978	960	950	940	923	905	895	885	850	795	735	-	-		
	Med Low	2]		980	963	945	935	925	908	890	878	865	848	830	805	780	720	-	-		
	Low	1			795	778	760	738	715	705	695	678	660	650	640	575	530	-	-	-		
	High	5			1405	1380	1355	1333	1310	1275	1240	1208	1175	1135	1095	1015	895	775	-	-		
	Med High	4					1275	1265	1255	1245	1235	1215	1195	1168	1140	1105	1070	985	875	770	-	-
036	Med	3	9 x 7	1/2	1180	1163	1145	1135	1125	1110	1095	1085	1075	1060	1045	975	865	750	-	-		
	Med Low	2]		1125	1115	1105	1090	1075	1065	1055	1040	1025	1008	990	950	855	730	-	-		
	Low	1			835	823	810	793	775	758	740	723	705	690	675	640	570	-	-	-		
	High	5			1805	1793	1780	1770	1760	1740	1720	1710	1700	1688	1675	1655	1635	1590	1550	1475		
	Med High	4]		1695	1688	1680	1660	1640	1623	1605	1593	1580	1573	1565	1535	1505	1460	1395	1300		
042	Med	3	11 x 10	1	1605	1593	1580	1560	1540	1523	1505	1493	1480	1470	1460	1420	1380	1305	1205	1135		
	Med Low	2] [1510	1495	1480	1465	1450	1435	1420	1403	1385	1373	1360	1310	1250	1135	1055	1010		
	Low	1			1340	1323	1305	1283	1260	1245	1230	1213	1195	1175	1155	1040	915	875	-	-		
	High	5			2000	1990	1980	1968	1955	1940	1925	1920	1915	1910	1905	1880	1845	1790	1655	1505		
	Med High	4]		1840	1833	1825	1810	1795	1785	1775	1770	1765	1755	1745	1715	1670	1620	1540	1360		
048	Med	3	11 x 10	1	1755	1743	1730	1718	1705	1698	1690	1683	1675	1655	1635	1600	1555	1495	1435	1300		
	Med Low	2]		1645	1630	1615	1605	1595	1583	1570	1560	1550	1530	1510	1475	1420	1350	1265	1180		
	Low	1			1430	1413	1395	1385	1375	1358	1340	1320	1300	1275	1250	1170	1060	995	930	875		
	High	5			2455	2440	2425	2413	2400	2390	2380	2365	2350	2335	2320	2295	2245	2175	2085	2015		
	Med High	4]		2260	2250	2240	2223	2205	2195	2185	2168	2150	2133	2115	2085	2045	2005	1975	1930		
060	Med	3	11 x 10	1	2140	2123	2105	2095	2085	2065	2045	2033	2020	2005	1990	1960	1915	1870	1835	1790		
	Med Low	2	j i		2010	1995	1980	1963	1945	1935	1925	1908	1890	1873	1855	1825	1780	1745	1690	1645		
	Low	1			1815	1803	1790	1775	1760	1743	1725	1705	1685	1665	1645	1600	1565	1515	1470	1410		
	High	5			2500	2495	2490	2473	2455	2438	2420	2405	2390	2363	2335	2325	2280	2215	2120	1995		
	Med High	4]		2300	2295	2290	2270	2250	2233	2215	2200	2185	2168	2150	2115	2080	2040	1990	1915		
070	Med	3	11 x 10	1	2175	2163	2150	2138	2125	2100	2075	2060	2045	2030	2015	1980	1945	1905	1860	1820		
	Med Low	2]		2040	2028	2015	2000	1985	1965	1945	1930	1915	1898	1880	1850	1805	1760	1725	1685		
	Low	1	<u> </u>		1850	1833	1815	1800	1785	1765	1745	1728	1710	1683	1655	1615	1580	1530	1475	1300		

Factory settings are in Bold

Airflow values are with dry coil and standard 1 in. filter

5-Speed ECM Motor Connections



09/26/12

5-Speed ECM Constant Torque Motors

The 5-speed ECM is a 'Constant Torque' ECM motor and delivers air flow similar to a PSC but operates as efficiently as an variable speed ECM Motor. Because it's an ECM Motor, the 5-speed ECM can ramp slowly up or down like the variable speed ECM Motor. There are 5 possible speed taps available on the 5-speed ECM motor with #1 being the lowest airflow and #5 being the highest airflow. These speed selections are preset at the time of manufacture and are easily changed in the field if necessary.

5-Speed ECM Benefits:

- High efficiency
- Soft start
- 5 speeds with up to 4 speeds on-line
- Built in logic allows air flow to change with G, Y1, Y2 and W signals
- Super efficient low airflow continuous blower setting (G)

If more than one tap are energized at the same time, built in logic gives precedence to the highest tap number and allows air flow to change with G, Y1, Y2 and W signals. Each of those 5 speeds has a specific 'Torque' value programmed into the motor for each speed selection. As static pressure increases, airflow decreases resulting in less torque on the rotor. The motor responds only to changes in torque and adjusts its speed accordingly.

The 5-speed ECM motor is powered by line voltage but the motor speed is energized by 24VAC.

Power Connection - 3/16 in. quick connects - Line 1 (orange wire) to L, Ground (green wire) to G, Line 2 (for 208V-230V units) to N (brown wire).

Signal Connection - 1/4 in. quick connects - Common to C, 24VAC to Taps #1-5.

Applying 24VAC power between any of the motor taps 1-5 (1/4 in. quick connects) and common will signal the motor to run and regulate torque at the programmed level. The tap input voltage must be in the range 12-33VAC. The 5-speed ECM will have less variation over the operating static pressure range versus a PSC motor as well as a significant watts reduction due to the high motor efficiency.

Thermal Protection - Motor is electronically protected.

Locked Rotor Amps - If motor speed decreases below a programmed stall speed, the motor will shut down and after a delay period, the control will attempt to restart the motor.

The 5-speed ECM speed tap selections are as follows: The blue wire should be placed on the speed tap desired for the (G) continuous blower setting – factory wired to Tap 1.

The red wire should be placed on the speed tap desired during compressor operation (Y1 signal) – factory wired to Tap 3 or 4.

The gray wire is not factory wired to the motor and is tied to the wire harness. It is field connected and can be used with 3ht/2cl thermostats or IntelliZone to deliver the required air flow for the Y2 signal.

The tan wire should be placed on the speed tap desired for auxiliary heat (W signal) – factory wired to Tap 5.

Blower Performance Data cont.

Variable Speed ECM Motor

Model	Max	Blower	Motor					Air F	low Dip S	witch Set	ings				
wodei	ESP	Size	hp	1	2	3	4	5	6	7	8	9	10	11	12
015	0.50	9 x 7	1/2	300	400 L	500	600 M	700 H	800						
018	0.50	9 x 7	1/2	300	400 L	500	600 M	700 H	800						
024	0.50	9 x 7	1/2		400 L	500	600 M	700	800 H	900	1000	1100			
030	0.50	9 x 7	1/2		400	500 L	600	700 M	800	900	1000 H	1100			
036	0.50	9 x 7	1/2		400	500	600 L	700	800	900 M	1000	1100 H	1200		
042	0.50	11 x 10	1/2	500	600	700 L	875	1050	1150 M	1250	1325	1375 H	1475	1550	
048	0.50	11 x 10	1/2	500	600	700	875 L	1050	1150	1250	1325 M	1375	1475	1550 H	1600
060	0.75	11 x 10	1	600	800	1000 L	1300	1500 M	1750	1950 H	2100	2200	2300		
070	0.75	11 x 10	1	600	800	1000 L	1300	1500	1750 M	1950	2100 H	2200	2300		

Factory settings are at recommended L-M-H DIP switch locations.

09/26/12

Shaded regions are recommended for best performance. It is acceptable to operate outside of this area as long as the WSHP operates within the guidelines of the Operating Limits table and Correction Factor tables.

Lowest and Highest DIP switch settings are assumed to be L and H respectively.

CFM is controlled within ±5% up to the maximum esp.

Max esp includes allowance for wet coil and standard filter

Setting Blower Speed - Variable Speed ECM

Variable speed ECM blower motors have 12 selectable speeds and are factory set for optimum performance. To change speeds on an FX10 control, use the Medium User Interface (MUI) to enter the MAINT menu to adjust the 12 soft switches. When applicable, the speed settings may also be adjusted through the Building Automation System (BAS).



CAUTION: Disconnect all power before performing this operation.

Blower Performance Data cont.

Setting Blower Speed - Variable Speed ECM

The ABC board's Yellow Config LED will flash the current variable speed ECM blower speed selections for low, med, and high continuously with a short pause in between. The speeds can also be confirmed with the AID Tool under the Setup/ECM Setup screen. The variable speed ECM blower motor speeds can be field adjusted with or without using an AID Tool.

Variable Speed ECM Setup without an AID Tool

The blower speeds for Low (G only), Med (Y1), and High (Y2/Aux) can be adjusted directly at the Aurora ABC board which utilizes the push button (SW1) on the ABC board. This procedure is outlined in the Variable Speed ECM Configuration Mode portion of the Aurora 'Base' Control System section.

Variable Speed ECM Setup with an AID Tool


A much easier method utilizes the AID Tool to change the airflow using the procedure below. First navigate to the Setup screen and then select ECM Setup. This screen displays the current variable speed ECM settings. It allows the technician to enter the setup screens to change the variable speed ECM settings. Change the highlighted item using the ◀ and ▶ buttons and then press the ▶ button to select the item.

Variable Speed ECM Setup with an AID Tool cont.



Selecting YES will enter variable speed ECM speed setup, while selecting NO will return to the previous screen.


Variable Speed ECM Speed Setup - These screens allow the technician to select the low, medium, and high blower speed for the variable speed ECM blower motor. Change the highlighted item using the ▲ and ▼ buttons. Press the ■ button to select the speed.



After the high speed setting is selected the AID Tool will automatically transfer back to the ECM Setup screen.


Wiring Schematics

Aurora Base Control 208-230/60/1 PSC




25







Aurora Base Control 460/60/3 5-Speed ECM




FX10 Control 208-230-265/60/1 PSC



FX10 Control 460/60/3 Variable Speed ECM



FX10 Control 460/60/3 5-Speed ECM



Controls - Aurora Base Control

Aurora 'Base' Control



NOTE: Refer to the Aurora Base Control Application and Troubleshooting Guide and the Instruction Guide: Aurora Interface and Diagnostics (AID) Tool for additional information.

Control Features

Software ABC Standard Version 2.0

Single or Dual Capacity Compressors

Either single or dual capacity compressors can be operated.

ECM Blower Motor Option

An ECM blower motor can be driven directly using the onboard PWM output. Four blower speeds are available based upon the G, Y1, Y2, and W input signals to the board. The blower speeds can be changed either by the ECM manual configurations mode method or by using the Aurora AID Tool directly. All four blower speeds can be set to the same speed if desired.

5-Speed ECM Blower Motor Option

A 5-Speed ECM blower motor will be driven directly using the thermostat connections. Any of the G, Y1, or Y2/W signals can drive any of the 5 available pre-programmed blower speeds on the motor.

Other Control Features

- · Random start at power up
- Anti-short cycle protection
- · High and low pressure cutouts
- · Loss of charge
- Water coil freeze detection
- · Air coil freeze detection
- Over/under voltage protection
- Condensate overflow sensor
- Load shed
- Dehumidification (where applicable)
- · Emergency shutdown
- Hot gas reheat operation (where applicable)
- Diagnostic LED
- · Test mode push button switch
- Two auxiliary electric heat outputs
- Alarm output
- · Accessory output with N.O. and N.C.
- Modbus communication (master)
- Modbus communication (slave)

Field Selectable Options via Hardware

DIP Switch (SW1) – Test/Configuration Button (See SW1 Operation Table)

Test Mode

The control is placed in the test mode by holding the push button switch SW1 for 2 - 5 seconds. In test mode most of the control timings will be shortened by a factor of sixteen (16). LED3 (green) will flash at 1 second on and 1 second off. Additionally, when entering test mode LED1 (red) will flash the last lockout one time. Test mode will automatically time out after 30 minutes. Test mode can be exited by pressing and holding the SW1 button for 2 to 5 seconds or by cycling the power. **NOTE:** Test mode will automatically be exited after 30 minutes.

ECM Configuration Mode

The control is placed in the ECM configuration mode by holding the pushbutton switch SW1 for 5 to 10 seconds, the high, low, and "G" ECM speeds can be selected by following the LED display lights. LED2 (yellow) will fast flash when entering the ECM configuration. When setting "G" speed LED3 (green) will be continuously lit, for low speed LED1 (red) will be continuously lit, and for high speed both LED3 (green) and LED1 (red) will be continuously lit. During the ECM configuration mode LED2 (yellow) will flash each of the 12 possible blower speeds 3 times. When the desired speed is flashed press SW1, LED2 will fast flash until SW1 is released. "G" speed has now been selected. Next select low speed, and high speed blower selections following the same process above. After third selection has been made, the control will exit the ECM configuration mode. Aux fan speed will remain at default or current setting and requires the AID Tool for adjustment.

Reset Configuration Mode

The control is placed in reset configuration mode by holding the push button switch SW1 for 50 to 60 seconds. This will reset all configuration settings and the EEPROM back to the factory default settings. LED3 (green) will turn off when entering reset configuration mode. Once LED3 (green) turns off, release SW1 and the control will reset.

DIP Switch (SW2)

SW2-1 FP1 Selection – Low water coil temperature limit setting for freeze detection. On = 30°F; Off = 15°F.

SW2-2 FP2 Selection – On = 30°F; Off = N/A

SW2-3 RV – O/B - thermostat type. Heat pump thermostats with "O" output in cooling or "B" output in Heating can be selected. On = O: Off = B.

SW2-4 Access Relay Operation (P2)

and 2-5

Access Relay Operation	SW2-4	SW2-5
Cycle with Blower	ON	ON
Cycle with Compressor	OFF	OFF
Water Valve Slow Opening	ON	OFF
Cycle with Comm. T-stat Hum Cmd	OFF	ON

Controls - Aurora Base Control cont.

Cycle with Blower - The accessory relay will cycle with the blower output.

Cycle with Compressor - The accessory relay will cycle with the compressor output.

Water Valve Slow Opening - The accessory relay will cycle and delay both the blower and compressor output for 90 seconds.

SW2-6 CC Operation – selection of single or dual capacity compressor. On = Single Stage; Off = Dual Capacity

SW2-7 Lockout and Alarm Outputs (P2) – selection of a continuous or pulsed output for both the LO and ALM Outputs. On = Continuous; Off = Pulsed

SW2-8 Future Use

Alarm Jumper Clip Selection

From the factory, ALM is connected to 24 VAC via JW2. By cutting JW2, ALM becomes a dry contact connected to ALG.

ECM Blower Speeds

The blower speeds can be changed either by using the ECM manual configurations mode method or by using the Aurora AID Tool directly (see Instruction Guide: Aurora Interface and Diagnostics (AID) Tool topic).

Field Selectable Options via Software

(Selectable via the Aurora AID Tool)

ECM Blower Speeds

An ECM blower motor can be driven directly using the onboard PWM output. Four blower speeds are available, based upon the "G", Y1 (low), Y2 (high), and Aux input signals to the board. The blower speeds can be changed either by the ECM manual configurations mode method (see ECM Configuration Mode topic) or by using the Aurora AID Tool directly. All four blower speeds can be set to the same speed if desired. Aux blower speed will remain at default or current setting and requires the AID Tool for adjustment.

Safety Features

The following safety features are provided to protect the compressor, heat exchangers, wiring and other components from damage caused by operation outside of design conditions.

Fuse – a 3 amp automotive type plug-in fuse provides protection against short circuit or overload conditions.

Anti-Short Cycle Protection – 4 minute anti-short cycle protection for the compressor.

Random Start - 5 to 80 second random start upon power up.

Fault Retry – in the fault condition, the control will stage off the outputs and then "try again" to satisfy the thermostat Y input call. Once the thermostat input calls are satisfied, the control will continue on as if no fault occurred. If 3 consecutive faults occur without satisfying the thermostat Y input call, then the control will go to Lockout mode.

Lockout – when locked out, the blower will operate continuously in "G" speed, and PSC blower motor output will remain on. The Alarm output (ALM) and Lockout output (L) will be turned on. The fault type identification display LED1 (Red) shall flash the fault code. To reset lockout conditions with SW2-8 On, thermostat inputs "Y1", "Y2", and "W" must be removed for at least 3 seconds. To reset lockout conditions with SW2-8 Off, thermostat inputs "Y1", "Y2", "W", and "DH" must be removed for at least 3 seconds. Lockout may also be reset by turning power off for at least 30 seconds or by enabling the emergency shutdown input for at least 3 seconds.

Lockout With Emergency Heat - if the control is locked out in the heating mode, and a Y2 or W input is received, the control will operate in the emergency heat mode while the compressor is locked out. The first emergency heat output will be energized 10 seconds after the W input is received, and the blower will shift to high speed. If the control remains locked out, and the W input is present, additional stage of emergency heat will stage on after 2 minutes. When the W input is removed, all of the emergency heat outputs will turn off, and the ECM blower will shift to "G" speed and PSC blower motor output will remain on.

High Pressure – fault is recognized when the Normally Closed High Pressure Switch, P4-9/10 opens, no matter how momentarily. The High Pressure Switch is electrically in series with the Compressor Contactor and serves as a hard-wired limit switch if an overpressure condition should occur.

Low Pressure - fault is recognized when the Normally Closed Low Pressure Switch, P4-7/8 is continuously open for 30 seconds. Closure of the LPS any time during the 30 second recognition time restarts the 30 second continuous open requirement. A continuously open LPS shall not be recognized during the 2 minute startup bypass time.

Loss of Charge – fault is recognized when the Normally Closed Low Pressure Switch, P4-7/8 is open prior to the compressor starting.

Condensate Overflow - fault is recognized when the impedance between this line and 24 VAC common or chassis ground drops below 100K ohms for 30 seconds continuously.

Freeze Detection (Coax) - set points shall be either 30°F or 15°F. When the thermistor temperature drops below the selected set point, the control shall begin counting down the 30 seconds delay. If the thermistor value rises above the selected set point, then the count should reset. The resistance value must remain below the selected set point for the entire length of the appropriate delay to be recognized as a fault. This fault will be ignored for the initial 2 minutes of the compressor run time.

Freeze Detection (Air Coil) - uses the FP2 input to protect against ice formation on the air coil. The FP2 input will operate exactly like FP1 except that the set point is 30 degrees and is not field adjustable.

Controls - Aurora Base Control cont.

Over/Under Voltage Shutdown - An over/under voltage condition exists when the control voltage is outside the range of 18 VAC to 30 VAC. If the over/under voltage shutdown lasts for 15 minutes, the lockout and alarm relay will be energized. Over/under voltage shutdown is self-resetting in that if the voltage comes back within range of 18 VAC to 30 VAC for at least 0.5 seconds, then normal operation is restored.

Operation Description

Power Up - The unit will not operate until all the inputs and safety controls are checked for normal conditions. The unit has a 5 to 80 second random start delay at power up. Then the compressor has a 4 minute anti-short cycle delay after the random start delay.

Standby In standby mode, Y1, Y2, W, DH, and G are not active. Input O may be active. The blower and compressor will be off.

Heating Operation

Heating, 1st Stage (Y1) - The blower is started on "G" speed immediately and the compressor is energized 10 seconds after the Y1 input is received. The ECM blower motor is switched to low speed 15 seconds after the Y1 input.

Heating, 2nd Stage (Y1, Y2) - The compressor will be staged to full capacity 20 seconds after Y2 input is received. The ECM blower will shift to high speed 15 seconds after the Y2 input is received.

Heating, 3rd Stage (Y1, Y2, W) - The hot water pump is deenergized and the first stage of electric heat is energized 10 seconds after the W command is received. If the demand continues the second stage of electric heat will be energized after 5 minutes.

Emergency Heat (W) - The blower will be started on "G" speed, 10 seconds later the first stage of electric heat will be turned on. 5 seconds after the first stage of electric heat is energized the blower will shift to Aux speed. If the emergency heat demand is not satisfied after 2 minutes the second electric heat stage will be energized.

Blower (G) - The blower will start immediately upon receiving a thermostat G command. If there are no other commands from the thermostat the ECM will run on "G" speed until the G command is removed. Regardless of blower input (G) from the thermostat, the blower will remain on for 30 seconds at the end of each heating cycle.

Cooling Operation

In all cooling operations, the reversing valve directly tracks the O input. Thus, anytime the O input is present, the reversing valve will be energized.

Cooling, 1st Stage (Y1, 0) - The blower is started on "G" speed immediately and the compressor is energized 10 seconds after the Y1 input is received. The ECM blower motor is switched to low speed 15 seconds after the Y1 input.

Cooling, 2nd Stage (Y1, Y2, 0) - The compressor will be staged to full capacity 20 seconds after Y2 input is received. The ECM blower will shift to high speed 15 seconds after the Y2 input is received.

Blower (G) - The blower will start immediately upon receiving a thermostat G command. If there are no other commands from the thermostat the ECM will run on "G" speed until the G command is removed. Regardless of blower input (G) from the thermostat, the blower will remain on for 30 seconds at the end of each heating, cooling, and emergency heat cycle.

Dehumidification (Y1, O, DH or Y1, Y2, O, DH) - When a DH command is received from the thermostat during a compressor call for cooling the ECM blower speed will be reduced by 15% to increase dehumidification.

Emergency Shutdown - Four (4) seconds after a valid ES input, P2-7 is present, all control outputs will be turned off and remain off until the emergency shutdown input is no longer present. The first time that the compressor is started after the control exits the emergency shutdown mode, there will be an anti-short cycle delay followed by a random start delay. Input must be tied to common to activate.

Continuous Blower Operation - The blower output will be energized any time the control has a G input present, unless the control has an emergency shutdown input present. The blower output will be turned off when G input is removed.

Load Shed - The LS input disables all outputs with the exception of the blower output. When the LS input has been cleared, the antishort cycle timer and random start timer will be initiated. Input must be tied to common to activate.

Controls - Aurora Base Control cont.

Aurora 'Base' Control LED Displays

These three LEDs display the status, configuration, and fault codes for the control. These can also be read in plain English via the Aurora AID Tool.

Status LED (LED3, Green)

Description of Operation	Fault LED, Green
Normal Mode	ON
Control is Non-functional	OFF
Test Mode	Slow Flash
Lockout Active	Fast Flash
Dehumidification Mode	Flash Code 2
(Future Use)	Flash Code 3
(Future Use)	Flash Code 4
Load Shed	Flash Code 5
ESD	Flash Code 6
(Future Use)	Flash Code 7

Configuration LED (LED2, Yellow)

Description of Operation	Configuration LED, Yellow				
No Software Overwritten	Flashing ECM Setting				
DIP Switch was Overwritten	Slow Flash				
ECM Configuration Mode	Fast Flash				

Fault LED (LED1, Red)

	Red Fault LED	LED Flash Code*	Lockout	Reset/Remove
	Normal - No Faults	OFF	-	
ι	Fault - Input	1	No	Auto
Faults	Fault - High Pressure	2	Yes	Hard or Soft
Į Ķ	Fault - Low Pressure	3	Yes	Hard or Soft
Basic	Fault - Freeze Detection FP2	4	Yes	Hard or Soft
	Fault - Freeze Detection FP1	5	Yes	Hard or Soft
ABC	Fault - Condensate Overflow	7	Yes	Hard or Soft
Ā	Fault - Over/Under Voltage	8	No	Auto
	Fault - FP1 & FP2 Sensor Error	11	Yes	Hard or Soft

 $\bf NOTE:$ All codes >11 use long flash for tens digit and short flash for the ones digit. 20, 30, 40, 50, etc. are skipped.


Aurora Interface and Diagnostics (AID) Tool

The Aurora Interface and Diagnostics (AID) Tool is a device that is a member of the Aurora network. The AID Tool is used to troubleshoot equipment which uses the Aurora control via Modbus RTU communication. The AID Tool provides diagnostics, fault management, ECM setup, and system




configuration capabilities to the Aurora family of controls. An AID Tool is recommended, although not required, for ECM airflow settings. The AID Tool simply plugs into the exterior of the cabinet in the AID Tool port.

ABC Control Board Layout



Controls - FX10 (optional)

Optional FX10 Microprocessor and BAS Interface



The FX10 is a microprocessor based control that not only monitors and controls the heat pump but also can communicate any of this information back to the building automation system (BAS). This means that not only does the control monitor the heat pump at the unit you can also monitor and control many the features over the BAS. This clearly puts the FX10 in a class of its own.

The control will enumerate all fault conditions (HP, LP, CO, LOC, and Freeze Detection) over a BAS as well as display them on a medium user interface (MUI). HP, LP, CO and Freeze Detection faults can all be reset over a BAS. A Loss Of Charge fault can not be reset or bypassed until the problem has been corrected. A MUI is invaluable as a service tool for the building service team.

The unit can be commanded to run by a typical heat pump thermostat or run based on heating and cooling set points supplied by a BAS. The control board is wired with quick connect harnesses for easy field change out of a bad control board. All variable speed ECM blower speed settings can be changed over a BAS or with a MUI. The control has an input programmed to enable field installed emergency heat in the event that the compressor is locked out. This input can also be commanded on from a BAS as needed. An alarm history can be viewed through the MUI and will be held in memory until the unit is power cycled. Relative humidity can be read by a 0-5VDC humidity sensor that is displayed over the network. If you are using a variable speed ECM blower motor the control can enable dehumidification mode based on a set point in the control. The dehumidification set point itself can also be changed over a BAS or with a MUI. Dehumidification mode can also be enabled by the BAS. Because the FX10 is not factory configured to read CO2 levels, contact the factory for application assistance.

The FX10 control has unused analog and digital inputs for field installed items such as air temperature, water temperature, CO² or current status switches. The control has unused binary and PWM outputs that can be commanded over the BAS for field use.

An optional Medium User Interface (MUI) for control setup and advanced diagnostics is available with some mounting kits, MUIK3

- Panel mount version and the MUIK4-Wall mount version.

Zone Sensors

There are two options for zone sensors that can be used with the FX10 control. Both sensors use a Johnson controls A99 positive temperature coefficient type sensor. The TAXXJ02 has a set point adjustment now which will give the end user a +/- 5°F adjustment from the set point as well as a push button that can be used for temporary occupancy. The control leaves the factory set to operate with a TAXXJ02 sensor, the TAXXA04 sensor through a building automation system, or with a user interface.

Standard Features

- · Anti Short Cycle
- · High Pressure Protection
- Low Pressure Protection
- Freeze Detection
- · Loss Of Charge Detection
- Random Start
- · Display for diagnostics
- Reset Lockout at disconnect or through BAS
- 2 Accessory outputs
- Optional BAS add-on controls

DDC Operation and Connection

Other optional network protocol boards that can be added to the FX10 are:

- Johnson Control N2
- LonWorks
- BACnet
 - MS/TP @ 19,200 Baud rate
 - Limit devices to 30 on a single trunk line

Control and Safety Feature Details Emergency Shutdown

The emergency shutdown mode can be activated by a command from a facility management system or a closed contact on BI-2. The default state for the emergency shutdown data point is off. When the emergency shutdown mode is activated, all outputs will be turned off immediately and will remain off until the emergency shutdown mode is de-activated. The first time the compressor starts after the emergency shutdown mode has been de-activated, there will be a random start delay present.

Controls - FX10 (optional) cont.

Lockout Mode

Lockout mode can be activated by any of the following fault signals: refrigerant system high pressure, refrigerant system low pressure, freeze detection, and condensate overflow. When any valid fault signal remains continuously active for the length of its recognition delay, the controller will go into fault retry mode, which will turn off the compressor. After the Compressor short cycle delay, the compressor will attempt to operate once again. If three consecutive faults occur in 60 minutes during a single heating or cooling demand, the unit will go into lockout mode, turning off the compressor, enabling the alarm output, and setting the blower back to low speed operation until the controller is reset. If the control faults due to the low pressure input (BI-3) being open during the pre-compressor startup check, the control will go into lockout mode immediately, disabling the compressor from starting and enabling the alarm output (BO-6). The lockout condition can be reset by powering down the controller, by a command from the BAS, or by the holding the ESC and Return keys on the MUI for 5 seconds.



Freeze Detection (AI-5)

The freeze detection sensor will monitor the liquid refrigerant temperature entering the water coil in the heating mode. If the temperature drops below the freeze detection trip point for the recognition delay period, the condition will be recognized as a fault. The freeze detection trip point will be factory set for 30°F (-1°C) and will be field selectable for 15°F (-9°C) by removing a jumper wire on BI-5. The freeze detection fault condition will be bypassed 2 minutes at normal compressor startup, to allow the refrigeration circuit to stabilize. If the freeze detection sensor becomes unreliable at any time compressor operation will immediately be suspended until the problem is corrected. This should be displayed as an alarm on the BAS and the MUI. This alarm will be reported as a "Water Low Temp Limit" fault.

High Pressure (BI-11)

The high-pressure switch shall be a normally closed (NC) switch that monitors the systems refrigerant pressure. If the input senses the high-pressure switch is open it must disable the compressor output immediately and count the fault. The compressor minimum on time does not apply if the high-pressure switch opens. The compressor will not restart until the compressor short cycle time delay has been satisfied.

Low Pressure (BI-3)

The low-pressure switch shall be a normally closed (NC) switch that monitors the systems refrigerant pressure. The input shall be checked 15 seconds before compressor start up to be sure the pressure switch is closed and then ignored for the first 2 minutes after the compressor output (BO-2) is enabled. If the switch is open continuously for (30) seconds during compressor operation the compressor output (BO-2) will be disabled. The compressor will not restart until the compressor short cycle time delay has been satisfied.

Condensate Overflow

The condensate overflow sensing circuit will monitor the condensate level as a resistance input to Al-3. If the condensate water level rises resulting in the input resistance rising above the set point for the recognition delay period, the condition will be recognized as a fault. The condensate will be subjected to a (30) second lockout delay which requires that the fault be sensed for a continuous (30) seconds before suspending unit operation.

Alarm Output (BO-6)

The alarm output will be enabled when the control is in the lockout mode and will be disabled when the lockout is reset.

Test Mode

Raising the zone temperature input (Al-1) reading to 180–220°F or by holding the ESC and down arrow keys on the MUI for 5 seconds will put the control into test mode. In test mode the random start delay and the compressor fixed on delay time will both be shortened to 5 seconds and the reversing valve will be allowed to cycle with out shutting down the compressor. If an MUI is connected to the control LED 8 will flash and the words "Test Mode Enabled" will be shown on the LCD display when the control is in test mode. Test mode will be disabled after a power cycle, 30 minute timeout, or by holding the ESC and Up arrow keys on the MUI.

Sequence of Operation

Power Fail Restart

When the controller is first powered up, the outputs will be disabled for a random start delay. The delay is provided to prevent simultaneous starting of multiple heat pumps. Once the timer expires, the controller will operate normally.

Random Start Delay

This delay will be used after every power failure, as well as the first time the compressor is started after the control exits the unoccupied mode or the emergency shutdown mode. The delay should not be less than 1 second and not longer than 120 seconds. If the control is in test mode the random start delay will be shortened to 5 seconds.

Controls - FX10 (optional) cont.

Compressor Fixed On Delay Time

The Compressor Fixed On Delay Time will ensure that the compressor output (B02) is not enabled for 90 seconds after the control receives a call to start the compressor. This delay is adjustable from 30-300 seconds over a BAS or a MUI. If the control is in test mode the Compressor Fixed On Delay Timer will be shortened to 5 seconds.

Compressor Minimum On Delay

The compressor minimum on delay will ensure that the compressor output is enabled for a minimum of two (2) minute each time the compressor output is enabled. This will apply in every instance except in the event the high pressure switch is tripped or emergency shutdown then the compressor output will be disable immediately.

Compressor Short Cycle Delay Time

The compressor short cycle time delay will ensure that the compressor output will not be enabled for a minimum of five (5) minutes after it is disabled. This allows for the system refrigerant pressures to equalize after the compressor is disabled.

Heating Cycle

On a call for heating, the blower enable output and accessory output 2 will turn on immediately after the random start delay timer has been satisfied. If the compressor short cycle time delay has been satisfied, the compressor will turn on after the blower enable and accessory output 2 are on and the fixed compressor start delay timers have been satisfied. **NOTE:** Auxiliary heat output can be controlled over the BAS.

Set Point Control Mode

In set point control mode the reversing valve output will be disabled. As the temperature drops below the heating set point and begins to operate in the heating proportional band, the compressor (low capacity for two-stage compressors) output (BO-2) will be enabled. For units with two-stage compressors, a PI loop in the programming of the control will determine when the full capacity compressor output (BO-4) is to be enabled. The compressor must be operating in low capacity for a minimum of 30 seconds before the full capacity compressor output can be enabled. During low capacity compressor operation the variable speed ECM blower will operate in medium speed and will operate in high speed when the compressor is operating at full capacity.

Thermostat Control Mode

In thermostat mode the compressor will be cycled based on Y1 and Y2 calls from a room thermostat. When the control receives a Y1 command (BI-7) from the thermostat the low capacity compressor output (BO2) will be enabled and the variable speed ECM blower will operate in medium speed. When the control receives a Y2 command (BI-8) from the

thermostat the variable speed ECM blower will operate in high speed. During the heating cycle the reversing valve will be commanded into the off position.

Cooling Cycle

On a call for cooling, the blower enable output and accessory output 2 will turn on immediately after the random start delay timer has been satisfied. If the compressor short cycle time delay has been satisfied, the compressor will turn on after the blower enable and accessory output 2 are on and the fixed compressor start delay timers have been satisfied.

Set Point Control Mode

In set point control mode the reversing valve output will be enabled. As the temperature rises above the cooling set point and begins to operate in the cooling proportional band, the low capacity compressor output (BO-2) will be enabled. A PI loop in the programming of the control will determine when the full capacity compressor output (BO-4) is to be enabled. The compressor must be operating in low capacity for a minimum of 30 seconds before the full capacity compressor output can be enabled. During low capacity compressor operation the variable speed ECM blower will operate in medium speed and will operate in high speed when the compressor is operating at full capacity.

Thermostat Control Mode

In thermostat mode the compressor will be cycled based on Y1 and Y2 calls from a room thermostat. When the control receives a Y1 command (BI-7) from the thermostat the low capacity compressor output (BO2) will be enabled and the variable speed ECM blower will operate in medium speed. When the control receives a Y2 command (BI-8) from the thermostat the full capacity compressor output will be enabled and the variable speed ECM blower will operate in high speed. During the cooling cycle the reversing valve will be commanded into the "ON" position.

Variable Speed ECM Blower Operation

Blower speeds will be selected through the user interface or the facility management system. There will be a total of 12 speeds selectable with only three being selected at any one time. The lowest numbered speed selection set to ON will select the low-speed blower setting, the middle selection set to ON will select the medium-speed blower setting and the highest selection set to ON will select the high-speed blower setting. If all selections are set to OFF

Controls - FX10 (optional) cont.

the software shall select speed setting 10 for low-speed, 11 for medium-speed, and will select speed setting 12 for high speed. If only one selection is set to ON, that selection will set the low-speed blower setting, the medium-speed setting will be 11, and the high-speed setting will be speed 12. The maximum low-speed setting will be speed 3. In addition there is a low limit setting in the software to prevent the variable speed ECM blower speed from being set below acceptable limits for each unit size.

Emergency Heat/Network Enabled Output (BO-5)

This output is set from the factory to enable/disable emergency heat. If a problem occurs with the unit resulting in the compressor being locked out in heating mode, the control will automatically enable this output to turn on field installed electric heat. This output is interlocked with the blower proving input BI-6 (Blower proving sensors must be field supplied and installed). BI-6 must be connected to PB2 position 3 (see unit schematic) in the field if no blower proving sensor is desired. There is a configurable parameter available through a BAS network that must be enabled if this output is to be commanded over the BAS network. **NOTE:** For auto switch over, BO-5 must be set to "Emergency" using the MUI.

MUI Alarm History Reporting

If a fault occurs the fault will be recorded in history for display on the medium user interface in the History Menu. Each fault type will be displayed in the history menu with a number between 0 and 3. A reading of 3+ will mean that fault has occurred more than three times in the past. The history menu can be cleared with a power cycle only. Alarm date and time are not included in the history.

Inputs and Outputs Configuration Field Selectable Options


Freeze Detection Set Point (BI-5)

The freeze detection set point input allows you to adjust the freeze detection set point (AI-5). When the jumper is installed on BI-5 (Wire #24) the freeze detection set point is factory set for 30°F (-1°C). When the jumper on BI-5 (Wire #24) is removed the freeze detection set point will be 15°F (-9°C).

Accessory Outputs (BO-7 and BO-8)

Accessory Output 1 will be energized 90 seconds prior to the compressor output being energized. Accessory Output 2 will be energized with the blower output (BO-1). When the corresponding compressor output is turned off the accessory output will be deactivated immediately. These outputs are selectable for normally open or normally closed operation through the MUI or through the BAS.

FX10 User Interface (MUI) Physical Layout



Alarm LED - Indicates a Lock-Out or a bad Freeze Sensor

Power LED - Shows FX processor is operational

LED 1 - Flashing shows Compressor 1 running

LED 2 - Flashing shows Full Capacity Compressor running

LED 3 - On shows Fan running

LED 4 - On shows Reversing Valve in cool

LED 8 - Flashing shows unit in 'Test' Mode

Controls - FX10 (optional) cont.

MUI Menu Navigation for Single Compressor - Arbor Base Series Water-to-Air

Welcome

Info Status Temps Outputs Settings Maint Alarms Alm-History

Info
Water Source
Heat Pump
PROFXENV-XX


Status Run Mode Auto Eff Occup'y Occ Y1 Input OFF Y2 Input OFF G Input OFF O Input Heat/Cool Occ Input Temp Occ Inp OFF Condensate NML **Emg Input** Run Lo Press ON Hi Press ON Rndm Tmr 0 OFF BI-4 Input

Temps						
Zone Temp	77.2 °F					
Dis Air Temp	51.0 °F					
Eff Clg Setpt	70.0°F					
Eff Htg Setpt	66.0°F					
Water Coil	77.8°F					
Low WC Limit	30.0°F					
Humidity	56.7 %RH					
WarmCool Al	14.6					
WarmCoolAdj	0.2					

Outputs	
nvoFanStatus	ON
CmpCmd Status	OFF
Cmp Capacity	OFF
Rev Valve	Heat
X1 Output	OFF
X2 Output	OFF
PWMOut	98%
BO5	OFF
BO9	OFF
AO2 Output	0%

Settings								
Unit of Measure	F							
Occ Clg Setpt	73.9 °F							
Occ Htg Setpt	69.9 °F							
Unocc Clg	84.0 °F							
Unocc Htg	60.0 °F							
DeHumSetpt	0%							
SensorSelect	TAXXJ02							

Maintenance						
MinClgSetpt	60.0 °F					
MaxHtgSetpt	89.9 °F					
W Coil LoLim1	30.0 °F					
W Coil LoLim2	15.0 ⁰F					
TmpOccTime	120 min					
Rev VIv Defa	ault Heating					
BO5 Mode	Network					
CompStrtDly	90 sec					
SpaceT Offset	-1 °F					
DehumEnaDis	Dis					
Acc1 Action	On Comp					
Acc2 Action	On Fan					



No more than three speeds should be "ON" at one time

Alarms

ALARM SUMMARY

^/High Pressure

Alm-History	,
-------------	---

Alarm	#Events
Condensate	0
Hi Pressure	0
Low Pressure	0
Low Temp	0
Bad Sensor	0

NOTE: This FX10 application implements an **alarm history** which is reset only by cycling power. This history shows on the Alm-History page. Any alarm showing 4+ events has occurred more than 4 times.

Alarm lock-outs are reset by cycling power, by pressing the "ESC" and Return ← keys simultaneously for a minimum of 15 seconds, or by commanding the nviAlarmReset over the BAS network.

Test mode is enabled by holding the 'Esc' and Down Arrow simultaneously for a minimum of 15 seconds and releasing. Test mode times out after 30 minutes, and may also be ended by pressing 'ESC' and Up Arrow simultaneously and releasing . Test Mode bypasses the On Delay (90 sec) and Random Start timers for quicker troubleshooting. It also allows cycling the reversing valve without compressor shutdown.

Unit Startup

Before Powering Unit, Check The Following:

NOTE: Remove and discard the compressor shipping bolts. The bolts can then be discarded.

- · High voltage is correct and matches nameplate.
- · Fuses, breakers and wire size correct.
- Low voltage wiring complete.
- · Piping completed and water system cleaned and flushed.
- · Air is purged from closed loop system.
- Isolation valves are open, water control valves or loop pumps wired.
- · Condensate line open and correctly pitched.
- · Transformer switched to 208V if applicable.
- Dip switches are set correctly.
- Blower rotates freely foam shipping support has been removed.
- Blower speed correct.
- Air filter/cleaner is clean and in position.
- Service/access panels are in place.
- Return air temperature is between 50-80°F heating and 60-95°F cooling.
- Check air coil cleanliness to insure optimum performance. Clean as needed according to maintenance guidelines. To
 obtain maximum performance the air coil should be cleaned before startup. A 10-percent solution of dishwasher
 detergent and water is recommended for both sides of coil, a thorough water rinse should follow.

Startup Steps

NOTE: Complete the Equipment Start-Up/Commissioning Check Sheet during this procedure. Refer to thermostat operating instructions and complete the startup procedure.

- 1. Initiate a control signal to energize the blower motor. Check blower operation.
- 2. Initiate a control signal to place the unit in the cooling mode. Cooling setpoint must be set below room temperature.
- Cooling will energize after a time delay. Check for correct rotation of scroll compressors in 3 phase applications. Incorrect rotation will cause low refrigerant pressures and possibly unusual noise. Switch any two power leads at the compressor or contactor to reverse rotation.
- 4. Be sure that the compressor and water control valve or loop pump(s) are activated.
- Verify that the water flow rate is correct by measuring the pressure drop through the heat exchanger using the P/T plugs and comparing to the pressure drop table.
- 6. Check the temperature of both the supply and discharge water (Refer to Operating Parameters tables).
- 7. Check for an air temperature drop of 15°F to 25°F across the air coil, depending on the blower speed and entering water temperature.
- 8. Decrease the cooling set point several degrees and verify high-speed blower operation (variable speed ECM only).
- 9. Adjust the cooling setpoint above the room temperature and verify that the compressor and water valve or loop pumps deactivate.
- 10. Initiate a control signal to place the unit in the heating mode. Heating set point must be set above room temperature.
- 11. Heating will energize after a time delay.
- 12. Check the temperature of both the supply and discharge water (Refer to Unit Operating Parameters tables).
- 13. Check for an air temperature rise of 20°F to 35°F across the air coil, depending on the blower speed and entering water temperature.
- 14. If auxiliary electric heaters are installed, increase the heating setpoint until the electric heat banks are sequenced on. All stages of the auxiliary heater should be sequenced on when the thermostat is in the Emergency Heat mode. Check amperage of each element.
- 15. Adjust the heating setpoint below room temperature and verify that the compressor and water valve or loop pumps deactivate.
- 16. During all testing, check for excessive vibration, noise or water leaks. Correct or repair as required.
- 17. Set system to desired normal operating mode and set temperature to maintain desired comfort level.
- 18. Instruct the owner/operator in the proper operation of the thermostat and system maintenance.

NOTE: Be certain to fill out and forward all warranty registration papers.

Operating Parameters

Futarina Water	Meter Flam		Cooling						
Entering Water Temp °F	Water Flow GPM/ton	Suction Pressure psig	Discharge Pressure psig	Superheat	Subcooling	Water Temp Rise °F	Air Temp Drop °F DB		
30	1.5	100-115	170-190	17 - 26	10 - 14	18 - 22	18 - 22		
30	3.0	95-110	150-170	20 - 29	7 - 11	8 - 10	18 - 22		
50	1.5	133 - 148	205 - 225	17 - 26	10 - 14	18 - 22	18 - 22		
50	3.0	129 - 144	185 - 205	20 - 29	7 - 11	8 - 10	18 - 22		
70	1.5	139 - 154	280 - 300	8 - 11	8 -12	18 - 22	18 - 22		
70	3.0	137 - 152	250 - 270	9 - 12	7 - 11	8 - 10	18 - 22		
90	1.5	143 - 158	360 - 380	8 - 11	9 - 13	18 - 22	16 - 20		
90	3.0	141 - 156	330 - 350	9 - 12	8 - 12	8 - 10	16 - 20		
440	2.3	143 - 158	360 - 380	8 - 11	9 - 13	18 - 22	16 - 20		
110	3.0	141 - 156	440-460	9 - 12	8 - 12	8 - 10	16 - 20		

Entering Motor	Water Flow		Heating							
Entering Water Temp °F	GPM/ton	Suction Pressure psig	Discharge Pressure psig	Superheat	Subcooling	Water Temp Drop °F	Air Temp Rise °F DB			
30	1.5	73 - 79	279 - 304	7 - 13	2 - 6	7 -10	18 - 24			
30	3.0	79 - 85	285 - 310	8 - 14	2 - 6	3 - 6	20 - 26			
50	1.5	103 - 109	308 - 333	8 - 12	4 - 8	8 - 11	20 - 26			
50	3.0	110 - 116	315 - 340	9 - 13	4 - 8	4 - 7	22 - 28			
70	1.5	140 - 146	330 - 365	10 - 14	7 - 11	11 - 14	26 - 32			
	3.0	146 - 153	340 - 375	10 - 14	7 - 11	7 - 10	28 - 34			
90	1.5	170-177	425-460	14-18	12-16	8-11	42-50			
90	3.0	174-181	435-470	14-18	12-16	8-11	42-50			
110	2.3									
110	3.0									

NOTES: Cooling performance based on entering air temperatures of 80°F DB, 67°F WB. Heating performance based on entering air temperature of 70°F DB.

5/1/1

Operating Limits

Operating Limits	Coo	ling	Heating	
Operating Limits	(°F)	(°C)	(°F)	(°C)
Air Limits				
Min. Ambient Air	45	7.2	45	7.2
Rated Ambient Air	80	26.7	70	21.1
Max. Ambient Air	100	37.8	85	29.4
Min. Entering Air	50	10.0	40	4.4
Rated Entering Air db/wb	80.6/66.2	27/19	68	20.0
Max. Entering Air db/wb	110/83	43/28.3	80	26.7
Water Limits				
Min. Entering Water	30	-1.1	20	-6.7
Normal Entering Water	50-110	10-43.3	30-70	-1.1
Max. Entering Water	120	48.9	90	32.2

NOTE: Minimum/maximum limits are only for start-up conditions, and are meant for bringing the space up to occupancy temperature. Units are not designed to operate at the minimum/maximum conditions on a regular basis. The operating limits are dependent upon three primary factors: 1) water temperature, 2) return air temperature, and 3) ambient temperature. When any of the factors are at the minimum or maximum levels, the other two factors must be at the normal level for proper and reliable unit operation.

Pressure Drop

[]		Pressure Drop (psi)						
Model	GPM	30°F	50°F	70°F	90°F	110°F		
	1.0	1.2	1.2	1.1	1.0	1.0		
006	1.5	2.2	2.0	1.9	1.8	1.7		
006	2.0	3.3	3.1	2.9	2.7	2.5		
	2.5	4.1	3.8	3.4	3.1	2.9		
	1.5	1.9	1.7	1.5	1.3	1.1		
009	2.0	3.0	2.8	2.6	2.4	2.2		
009	3.0	6.3	6.3	6.1	5.9	5.7		
	4.0	8.1	7.9	7.4	6.8	6.1		
	1.5	1.1	1.1	1.0	0.9	0.9		
012	2.5	2.4	2.3	2.2	2.0	1.9		
012	3.5	4.2	4.0	3.7	3.4	3.2		
	4.5	6.1	5.9	5.2	4.7	4.1		
	2.0	1.8	1.7	1.6	1.4	1.2		
015	3.0	3.3	3.1	2.9	2.6	2.3		
013	4.0	5.0	4.9	4.8	4.7	4.6		
	5.0	7.1	6.7	5.9	5.4	5.1		
	3.0	3.3	3.2	3.0	2.8	2.6		
018	4.0	4.7	4.2	3.9	3.6	3.1		
0.0	5.0	6.2	5.2	4.7	4.1	3.5		
	6.0	7.7	6.2	5.4	4.6	3.8		
	3.0	3.2	3.1	2.9	2.7	2.5		
024	4.5	6.1	5.5	4.9	4.5	4.2		
"-"	6.0	9.0	7.9	6.9	6.3	5.8		
	8.0	12.9	10.9	9.5	8.8	7.9		
	4.0	2.4	2.3	2.2	2.0	1.8		
030	6.0	5.1	4.9	4.7	4.5	4.3		
	8.0	7.8	7.5	7.1	6.9	6.7		
	10.0	10.5	10.1	9.6	9.3	8.9		
	5.0	2.0	1.9	1.7	1.5	1.4		
036	7.0	3.6	3.5	3.3	3.1	2.9		
	9.0	5.2	5.1	4.8	4.6	4.4		
	12.0	7.5	7.4	7.1	6.9	6.7		
	5.0	2.1	2.0	1.8	1.6	1.4		
042	8.0	4.8	4.7	4.5	4.4	4.2		
	11.0	7.5	7.4	7.0	6.6	6.1		
	14.0	10.1	9.9	9.6	8.8	8.1		
	6.0	2.7	2.6	2.4	2.2	2.0		
048	9.0	6.0	5.9	5.4	5.2	5.1		
	12.0	9.5	9.3	8.5	8.3	8.1		
	16.0	14.2	13.9	12.7	12.3	12.1		
	9.0	4.5	4.4	4.2	4.0	3.8		
060	12.0	6.5	6.3	6.1	5.9	5.7		
	15.0	8.6	8.1	7.9	7.7	7.5		
	20.0	12.1	11.2	10.8	10.6	10.4		
	12.0	5.7	5.6	5.4	5.2	5.0		
070	15.0	8.9	8.6	8.2	7.7	6.7		
	18.0	12.0	11.5	11.0	10.1	8.4		
	24.0	17.4	16.9	16.5	15.1	11.8		

Valve	GPM	Cv	Pressure Drop (psi)					
Internally mounted 2-position solenoid water valves are not available on models 006-012								
	3.0	9.9	0.09					
	4.0	10.1	0.16					
1/2"	5.0	10.4	0.23					
	6.0	10.6	0.32					
	3.0	9.9	0.09					
	4.0	10.1	0.16					
1/2"	5.0	10.4	0.23					
	6.0	10.6	0.32					
3/4"	3.0	9.9	0.09					
	4.5	10.2	0.19					
	6.0	10.6	0.32					
	8.0	11.0	0.53					
	4.0	10.1	0.16					
	6.0	10.6	0.32					
3/4"	8.0	11.0	0.53					
	10.0	11.5	0.76					
	5.0	10.4	0.23					
	7.0	10.8	0.42					
3/4"	9.0	11.2	0.64					
	12.0	11.9	1.02					
	5.0	10.4	0.23					
	8.0	11.0	0.53					
3/4"	11.0	11.7	0.89					
	14.0	12.3	1.29					
	6.0	10.6	0.32					
	9.0	11.2	0.64					
3/4"	12.0	11.9	1.02					
	16.0	12.8	1.57					
	9.0	16.8	0.29					
	12.0	17.4	0.47					
1"	15.0	18.1	0.69					
	20.0	19.2	1.09					
	12.0	17.4	0.47					
	15.0	18.1	0.69					
1"	18.0	18.7	0.92					

9/5/12

9/5/12

Compressor and Thermistor Resistance

Compressor Resistance

Madal	115/	60/1	208-23	0/60/1	265/	/60/1	200 220/60/2	460/60/3	575/60/4
Model	Run	Start	Run	Start	Run	Start	208-230/60/3		
006	1.25-1.43	2.70-3.10	5.30-6.09	5.12-5.89	8.33-9.59	4.25-4.89			
009	0.77-0.89	1.79-2.05	3.65-4.19	3.75-4.31	3.73-4.27	4.45-5.13			
012	Not Available at T	ime of Publication	3.35-3.85	2.80-3.22	3.73-4.27	4.45-5.13			
015			2.74-3.16	2.60-3.00	3.03-3.49	2.39-2.75			
018			2.24-2.58	2.84-3.26	3.03-3.49	2.39-2.75			
024			1.36-1.50	2.26-2.50	1.33-1.47	2.34-2.58	1.29-1.43	5.06-5.6	
030			0.93-1.03	1.64-1.82	1.33-1.47	2.34-2.58	1.29-1.43	5.06-5.6	
036			0.60-0.66	1.20-1.32	0.76-0.84	1.67-1.85	1.09-1.21	4.38-4.84	
042			0.49-0.55	1.56-1.73			1.09-1.21	4.38-4.84	6.88-7.60
048			0.51-0.57	1.58-1.74			0.88-0.97	3.41-3.77	5.39-5.96
060			0.43-0.48	1.33-1.47			0.88-0.97	2.78-3.07	5.39-5.96
070			0.35-0.40	1.34-1.54			0.71-081	2.72-3.13	4.27-4.92

09/26/12

Thermistor Resistance

Thermistor	Microprocessor	FX10
Temperature (°F)	Resistance (Ohms)	Resistance (Ohms)
5	72,950	746-770
14	55,330	775-803
23	42,330	808-836
32	32,650	841-869
41	25,390	875-903
50	19,900	910-938
59	15,710	946-974
68	12,490	981-1013
77	10,000	1019-1051
86	8,057	1058-1090
95	6,530	1097-1129
104	5,327	1137-1169
113	4,370	1179-1211
122	3,603	1221-1253
131	2,986	1261-1297
140	2,488	1305-1341
149	2,083	1350-1386

5/1/11

Refrigerant Circuit Guideline

Symptom	Head Pressure	Suction Pressure	Compressor Amp Draw	Superheat	Subcooling	Air Temp. Differential	Water Temp. Differential
Under Charged System (Possible Leak)	Low	Low	Low	High	Low	Low	Low
Over Charged System	High	High	High	Normal	High	Normal/Low	Normal
Low Air Flow Heating	High	High	High	High/Normal	Low	High	Low
Low Air Flow Cooling	Low	Low	Low	Low/Normal	High	High	Low
Low Water Flow Heating	Low/Normal	Low/Normal	Low	Low	High	Low	High
Low Water Flow Cooling	High	High	High	High	Low	Low	High
High Air Flow Heating	Low	Low	Low	Low	High	Low	Low
High Air Flow Cooling	Low	High	Normal	High	Low	Low	Normal
High Water Flow Heating	Normal	Low	Normal	High	Normal	Normal	Low
High Water Flow Cooling	Low	Low	Low	Low	High	Normal	Low
Low Indoor Air Temperature Heating	Low	Low	Low	Normal	High	Normal	Normal/High
Low Indoor Air Temperature Cooling	Low	Low	Low	Normal/Low	High	Low	Low
High Indoor Air Temperature Heating	High	High	High	Normal/High	Normal/Low	Low	Normal
High Indoor Air Temperature Cooling	High	High	High	High	Low	Low	High
Restricted TXV (Check Service Advisory)	High	Low	Normal/Low	High	High	Low	Low
Insufficient Compressor (Possible Bad Valves)	Low	High	Low	High	Normal/High	Low	Low
TXV - Bulb Loss of Charge	Low	Low	Low	High	High	Low	Low
Scaled Coaxial Heat Exchanger Heating	Low	Low	Low	Normal/Low	High	Low	Low
Scaled Coaxial Heat Exchanger Cooling	High	High	High	Normal/Low	Low	Low	Low
Restricted Filter Drier		Che	eck temperature	difference (delta	T) across filter d	rier.	

7/6/10

Heat of Extraction/Rejection Data

Madal			Heat Of Ext	raction (HE)		Heat of Rejection (HR)					
Model	GPM	30°F	50°F	70°F	90°F	30°F	50°F	70°F	90°F	110°F	
	1.0		4.6	6.0	7.5		10.2	9.2	13.5		
006	1.5	3.6	4.7	6.1	7.7	9.8	10.1	9.3	13.3	8.2	
	2.0	3.1	4.8	6.2	7.8	9.8	10.1	9.3	13.2	8.3	
	1.5		6.2	7.7	10.0		11.9	11.1	10.1		
009	2.0	5.0	6.3	7.9	10.2	11.8	11.9	11.0	10.1	9.3	
	3.0	4.8	6.5	8.2	10.4	11.9	12.0	10.9	10.2	9.4	
	1.5		8.0	9.9	13.3		15.2	14.6	13.6		
012	2.5	6.6	8.4	10.4	13.5	14.6	15.1	14.7	13.6	11.6	
	3.5	6.4	8.7	10.9	13.7	14.7	15.0	14.8	13.6	11.7	
	2.0		9.2	11.5	13.4		18.9	18.0	17.0		
015	3.0	7.7	9.5	11.8	13.6	19.2	19.0	18.1	17.1	15.5	
	4.0	7.2	9.9	12.1	13.8	19.3	19.1	18.2	17.2	15.6	
	3.0		11.4	14.6	16.2		25.4	24.0	22.7		
018	4.0	9.2	11.7	14.7	16.5	25.2	25.1	23.6	22.7	21.7	
	5.0	8.9	11.9	14.8	16.8	25.3	24.9	23.3	22.9	21.8	
	3.0		15.9	20.2	22.5		32.6	30.8	28.8		
024	4.5	13.2	16.5	20.5	22.9	33.1	33.0	31.3	28.8	26.1	
	6.0	11.9	17.2	20.8	23.3	33.3	33.4	31.7	29.1	26.3	
	4.0		19.9	25.4	31.0		39.9	37.4	34.8		
030	6.0	16.1	20.7	26.5	31.5	39.0	40.3	37.7	34.8	31.4	
	8.0	14.5	21.6	27.6	32.0	39.2	40.7	38.1	35.2	31.6	
	5.0		24.8	32.3	38.1		48.6	46.4	43.0		
036	7.0	20.0	25.9	33.4	38.7	46.7	48.7	46.8	43.1	39.3	
	9.0	18.4	27.0	34.6	39.3	46.9	48.8	47.1	43.5	39.6	
	5.0		28.1	37.3	47.4		57.0	52.9	68.6		
042	8.0	22.8	29.9	39.0	48.2	54.7	57.6	53.4	68.7	44.9	
	11.0	22.1	31.6	40.7	49.0	55.0	58.1	54.0	69.2	45.3	
	6.0		33.7	44.8	58.0		69.2	64.8	59.5		
048	9.0	26.3	35.4	47.3	58.9	63.9	69.5	65.4	59.6	53.5	
	12.0	25.9	37.1	49.8	59.9	64.2	69.7	66.0	60.1	53.9	
	9.0		36.7	47.2	60.6		78.1	73.7	68.6		
060	12.0	28.8	38.0	49.9	61.6	74.0	78.4	74.1	68.7	62.2	
	15.0	28.6	39.3	52.6	62.6	74.3	78.6	74.4	69.2	62.6	
	12.0		47.7	63.7	78.4		88.8	86.1	79.5		
070	15.0	36.0	48.7	65.4	79.7	76.1	87.9	86.3	79.6	72.1	
	18.0	34.5	49.6	67.1	81.0	76.4	87.1	86.5	80.3	72.6	

Values displayed in MBtu/h 09/26/12

Reference Calculations

Heating Calculations:	Cooling Calculations:
$LWT = EWT - \frac{HE}{gpm \times 500}$	$LWT = EWT + \frac{HR}{gpm \times 500}$
$LAT = EAT + \frac{HC}{cfm \times 1.08}$	$LAT(DB) = EAT(DB) - \frac{SC}{cfm \times 1.08}$
	LC = TC - SC
TH = HC + HWC	$S/T = \frac{SC}{TC}$

Legend

ABBREVIATIONS AND DEFINITIONS:

cfm = airflow, cubic feet/minute

EWT = entering water temperature, Fahrenheit

gpm = water flow in gallons/minute

WPD = water pressure drop, PSI and feet of water

EAT = entering air temperature, Fahrenheit

(dry bulb/wet bulb)

HC = air heating capacity, MBtu/h
TC = total cooling capacity, MBtu/h

SC = sensible cooling capacity, MBtu/h

KW = total power unit input, kilowattsHR = total heat of rejection, MBtu/h

HE = total heat of extraction, MBtu/h

HWC = hot water generator capacity, MBtu/h

EER = Energy Efficient Ratio = BTU output/Watt input

COP = Coefficient of Performance

= BTU output/BTU input

LWT = leaving water temperature, °F LAT = leaving air temperature, °F TH = total heating capacity, MBtu/h LC = latent cooling capacity, MBtu/h

S/T = sensible to total cooling ratio

Troubleshooting

Should a major problem develop, refer to the following information for possible causes and corrective steps.

If compressor won't run:

- 1. The fuse may be open or the circuit breaker is tripped. Check electrical circuits and motor windings for shorts or grounds. Investigate for possible overloading. Replace fuse or reset circuit breakers after fault is corrected.
- 2. Supply voltage may be too low. Check it with a volt meter.
- 3. Control system may be faulty. Check control for correct wiring of thermostat or aquastat and check the 24 volt transformer for proper voltage.
- 4. Wires may be loose or broken. Replace or tighten.
- 5. The low pressure switch may have tripped due to one or more of the following:
 - a) Heating
 - 1) Plugged heat exchanger on source side
 - 2) Water flow source side (Low)
 - 3) Water too cold source side
 - 4) Low refrigerant
 - b) Cooling
 - 1) Plugged heat exchanger on load side
 - 2) Water flow load side (Low)
 - 3) Water too cold load side
 - 4) Low refrigerant
- 6. The high pressure switch may have tripped due to one or more of the following:
 - a) Heating
 - 1) Plugged heat exchanger on load side
 - 2) Low water flow load side
 - 3) Water too warm load side
 - b) Cooling
 - 1) Plugged heat exchanger on source side
 - 2) Low water flow on source side
 - 3) Water too warm source side
- 7. The compressor overload protection may be open.
- 8. The internal winding of the compressor motor may be grounded to the compressor shell. If so, replace the compressor.
- 9. The compressor winding may be open or shorted. Disconnect power. Check continuity with ohm meter. If the winding is open, replace the compressor.

If sufficient cooling or heating is not obtained:

- 1. Check control for improper location or setting.
- 2. Check for restriction in water flow.
- 3. Check refrigerant subcooling and superheat for proper refrigerant charge and expansion valve operation.
- 4. The reversing valve may be defective and creating a bypass of refrigerant. If the unit will not heat, check the reversing valve coil.

If the unit operation is noisy:

- 1. Check compressor for loosened mounting bolts. Make sure compressor is floating free on its isolator mounts. Check for tubing contact with the compressor or other surfaces. Readjust it by bending slightly.
- 2. Check screws on all panels.
- 3. Check for chattering or humming in the contactor or relays due to low voltage or a defective holding coil. Replace the component.
- 4. Check for proper installation of vibration absorbing material under the unit.
- 5. Check for abnormally high discharge pressures.
- 6. Compressor rotation incorrect

Refrigerant Systems

To maintain sealed circuit integrity, do not install service gauges unless unit operation appears abnormal. Compare the change in temperature on the air side as well as the water side to the Operating Parameters tables. If the unit's performance is not within the ranges listed, and the airflow and water flow are known to be correct, gauges should then be installed and superheat and subcooling numbers calculated. If superheat and subcooling are outside recommended ranges, an adjustment to the refrigerant charge may be necessary.

NOTE: Verify that air and water flow rates are at proper levels before servicing the refrigerant circuit.

Startup and Troubleshooting Form

Company Name:						
Technician Name:		Serial	l No.			
Owner's Name:		Open or Closed Loop:				
Installation Address:						
Check One						
☐ Start up/Check-out for new installation	☐ Troublesho	ooting	Problem:			
<u>`</u>						
1. FLOW RATE IN GPM (COAXIAL HEAT EXCHA	ANGER)					
Water In Pressure:	a					
Water Out Pressure:	b	PSI				
Pressure Drop = a - b Convert Pressure Drop to Flow Rate	C	PSI				
(refer to <i>Pressure Drop</i> table)	d	GPM				
0. TEMPERATURE DIOS OR DROP 4 OROGO O	047/141 11545		IOED.			
2. TEMPERATURE RISE OR DROP ACROSS CO						
Water In Temperature:	e	OLING °F	e. HEAT	°F	ı	
Water Out Temperature:	f	°F	f	°F		
Temperature Difference:	g	°F	g	°F		
3. TEMPERATURE RISE OR DROP ACROSS AII	R COII					
J. TEINI ERATORE RIGE OR BROT AGROOG AI		N INC	I UEAT	INC	ı	
Air In Temperature:	h	<u>°F</u>	h	°F	1	
Air Out Temperature:	i	°F	i	°F		
Temperature Difference:	j	°F	j	°F		
4. HEAT OF REJECTION (HR) / HEAT OF EXTRA	ACTION (HE)	CALCUL	ATION			
HR or HE = Flow Rate x Temperature Differ d. (above) x g. (above) x 485 for Methan Heat of Extraction (Heating Mode) = Heat of Rejection (Cooling Mode) = Compare results to Capacity Data Tables			water* btu/hr btu/hr			
Note: Steps 5 through 8 need only be completed if	f a problem is s	uspected	i			
5. WATTS						
· · · · · · ·	COC	LING	HEAT	ING	1	
Volts:	m	VOLTS	m	VOLTS		
Total Amps (Comp. + Fan): Watts = m. x n. x 0.85	n o	AMPS WATTS	n o.			
Watts = 111. X 11. X 0.05	0	WAITS	10	WAITS		
6. CAPACITY						
Cooling Capacity = HR (o. x 3.413)		p				
Heating Capacity= HE. + (o. x 3.413)		p	_ btu/hr			
7. EFFICIENCY						
Cooling EER = $p. / o.$		q				
Heating COP = p. / (o. x 3.413)		q	_ COP			
8. SUPERHEAT (S.H.) / SUBCOOLING (S.C.)						
0 " 0		LING	HEAT			
Suction Pressure: Suction Saturation Temperature:	r	PSI °F	r	PSI °F		
Suction Line Temperature:	s t	°F	s t	°F		
Superheat = t s.	u	°F	u	°F		
Head Pressure:	V	PSI	V	PSI		
High Pressure Saturation Temp.:	V W	°F	w	°F		
Liquid Line Temperature*:	x	°F	x	°F		
Subcooling = w x.	у	°F	у	°F		

^{*} Note: Liquid line is between the coaxial heat exchanger and the expansion valve in the cooling mode; between the air coil and the expansion valve in the heating mode.

Startup/Troubleshooting Form

Dealer: _____

Phone #: _____ Date: ____

Problem:

Model #:

Serial #: ____


Controls Info:

ABC Version: _____

AXB Version: _____

Installed Sensors:


COOLING CYCLE ANALYSIS



Heat of Extraction/Rejection = gpm x 500 (485 for water/antifreeze) x ∆T

Note: DO NOT hook up pressure gauges unless there appears to be a performance problem.

HEATING CYCLE ANALYSIS



Preventive Maintenance

Water Coil Maintenance

- Keep all air out of the water. An open loop system should be checked to ensure that the well head is not allowing air to infiltrate the water line. Lines should always be airtight.
- Keep the system under pressure at all times. It is recommended in open loop systems that the water control valve be placed in the discharge line to prevent loss of pressure during off cycles. Closed loop systems must have positive static pressure.

NOTE: On open loop systems, if the installation is in an area with a known high mineral content (125 PPM or greater) in the water, it is best to establish with the owner a periodic maintenance schedule so the coil can be checked regularly. Should periodic coil cleaning be necessary, use standard coil cleaning procedures which are compatible with either the cupronickel or copper water lines. Generally, the more water flowing through the unit the less chance for scaling.

Other Maintenance

Filters

Filters must be clean to obtain maximum performance. They should be inspected monthly under normal operating conditions and be replaced when necessary. Units should never be operated without a filter.

Condensate Drain

In areas where airborne bacteria produce a slime in the drain pan, it may be necessary to treat chemically to minimize the problem. The condensate drain can pick up lint and dirt, especially with dirty filters. Inspect twice a year to avoid the possibility of overflow.

Blower Motors

Blower motors are equipped with sealed ball bearings and require no periodic oiling.

Air Coil

The air coil must be cleaned to obtain maximum performance. Check once a year under normal operating conditions and, if dirty, brush or vacuum (with a brush attachment) clean. Care must be taken not to damage the aluminum fins while cleaning.



CAUTION: Fin edges are sharp.

Replacement Procedures

Obtaining Parts

When ordering service or replacement parts, refer to the model number and serial number of the unit as stamped on the serial plate attached to the unit. If replacement parts are required, mention the date of installation of the unit and the date of failure, along with an explanation of the malfunctions and a description of the replacement parts required.

In-Warranty Material Return

Material may not be returned except by permission of authorized warranty personnel. Contact your local distributor for warranty return authorization and assistance.

Service Parts - Vertical

		006	009	012	015	018	024	030	036	042	048	060	070
	Compressor 208-230/60/1	34P653-01	34P590-01	34P591-01	34P592-01	34P593-01	34P636-01	34P637-01	34P635-01	34P638-01	34P639-01	34P630-01	34P631-01
	265/60/1	34P653-02	34P590-02	34P591-02	34P592-02	34P593-02	34P636-02	34P637-02	34P635-02		Not A	/ailable	
	230/60/3			Not Available			34P636-03	34P637-03	34P635-03	34P638-03	34P639-03	34P630-03	34P631-03
	460/60/3	Not Available					34P636-04	34P637-04	34P635-04	34P638-04	34P639-04	34P630-04	34P631-04
sor	575/60/3				Not Av	/ailable				34P638-05	34P639-05	34P630-05	34P631-05
Compressor	115/60/1	34P653-09	34P590-09	34P591-09					Not Available	ı			
Com	Run Capacitor 208-230/60/1	16P002D12	16P002D17	16P002D18	16P0	02D19	16P00)2D19	16P002D20	16P002D21	16P002D32	16P00	02D23
	Run Capacitor 265/60/1		16P002D27	1	16P0	02D30	16P0)2D29	16P002D30		Not A	/ailable	
	Run Capacitor 115/60/1	16P002D21	16P00	D2D36					Not Available	ı			
	Sound Jacket			92P504A01				92P5	23-01			92P524-01	
	Discharge Muffler					Not Available						36P503B02	
Σ	VS ECM Motor 208-230/60/1		Not Available				14P515B01			14P5	16B01	14P5	17B01
Variable Speed ECM Motor & Blower	VS ECM Motor 265/60/1		Not Available				14P515B03				Not Av	/ailable	
Spee & Bk	VS ECM Motor 230/60/3			Not Available				14P515B01		14P5	16B01	14P5	17B01
able s	VS ECM Motor 460/60/3			Not Available				14P515B03		14P5	16B03	14P5	17B03
Varia	VS ECM Blower Housing		Not Available				53P512B01				53P5	15B01	
	PSC Motor 115/60/1		14P506-03						Not Available	l			
-ie	PSC Motor 208-230/60/1		14P506-02		14P5	07B01	14P508B01	14P509B01	14P510B01	14P511B01	14P512B01	14P5	14B01
PSC Motor & Blower	PSC Motor 265/60/1		14P506-02		14P5	07B02	14P508B02	14P509B02	14P510B02		Not A	ı ailable	
8 70	PSC Motor 230/60/3			Not Available	1		14P508B01	14P509B01	14P510B01	14P511B01	14P512B01	14P5	14B01
Mot	PSC Motor 460/60/3								14P511B02	14P512B02 14P514B02		14B02	
PSC	PSC Motor 575/60/3				Not Av	/ailable				14P511B03	14P512B03	03 14P514B03	
	PSC Blower & Housing						53P512B01		53P517-02			53P515B01	
	5-Speed ECM Motor 208-230/60/1	Not Available			ot Available 14S536-18		14S536-01	14S536-02	14S536-03	14S537-01	14\$537-02	14S537-03	14S537-03
CM	5-Speed ECM Motor 277/60/1		Not Available		14S5	36-19	14S536-02	14S536-07	14S536-08		Not A	/ailable	
5-Speed ECM Motor & Blower	5-Speed ECM Motor 230/60/3			Not Available			14P536-01	14\$536-02	14S536-03	14S537-01	14\$537-02	14S537-03	14S537-03
5-S Mot	5-Speed ECM Motor 460/60/3			Not Available	ı		14S536-03 14S536-10		14S536-11	14\$537-04 14\$537-05		14S537-06	14S537-06
	5-Speed ECM Blower & Housing		Not Available				53P512B01		T <u></u>		53P5	1	T
ė .	Air Coil		61P723-41	1		704-41 T		13-41 I	61P705-41	61P7	1	61P706-41	61P715-41
on C	Coax (Copper)	62P587-01	62P591-01	62P586-01	62P586-01	62P586-01	62P586-01	62P572-01	62P5	1	62P568-01	62P573-01	62P574-01
Refrigeration Components	TXV		33P605-19			33P605-16		33P6	05-02	l	05-10	33P608-10	33P605-13
Refrig	Reversing Valve	33P502-05	33P502-05	33P502-05			05-04			33P506-04		33P503-05	33P526-04
L.	Filter Drier				T	36P5	00B01					36P50	00B02
	Transformer 115/60/1		15P008B02						Not Available				
	Transformer 208-230/60/1						15P5	01B01		I			
s _o	Transformer 265/60/1				15P5	07B01					Not A	/ailable	
Controls	Transformer 230/60/3			Not Available			15P501B01						
	Transformer 460/60/3	Not Available								15P505B01			
	Transformer 575/60/3	Not Available					15P506B01						
	Phase Guard			Not Available						19P541A06			
Sensors & Safeties	High Pressure Switch						35P5	06B02					
Sen	Low Pressure Switch						35P5	06B01					

Part numbers subject to change 8/19/13

Service Parts - Horizontal

March Marc			006	009	012	015	018	024	030	036	042	048	060	070
Marie		Compressor 208-230/60/1	34P653-01	34P590-01	34P591-01	34P592-01	34P593-01	34P636-01	34P637-01	34P635-01	34P638-01	34P639-01	34P630-01	34P631-01
March Mar		•	34P653-02	34P590-02	34P591-02	34P592-02	34P593-02	34P636-02	34P637-02	34P635-02		Not Av	ailable	
Page Page		230/60/3	Not Available					34P636-03	34P637-03	34P635-03	34P638-03	34P639-03	34P630-03	34P631-03
\$\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \			Not Available								34P638-04	34P639-04	34P630-04	34P631-04
Page Page	šor	575/60/3				Not Av	/ailable				34P638-05			34P631-05
Page Page	ores	115/60/1	34P653-09	34P590-09	34P591-09					Not Available				
Run Capacitor 285601* 16P002D22* 16P002D206 16P002	Som	Run Capacitor 208-230/60/1	16P002D12		16P002D18	16P0	D2D19	16P00)2D19	16P002D20	16P002D21	16P002D32	16P00	D2D23
Run Capacitor 1156/01 1670000001 1670000001 167000000000000000000000000000000000000		· · · · · · · · · · · · · · · · · · ·		16P002D27		16P0	D2D30	16P00)2D29	16P002D30		Not Av	ailable	
Discharge Muffler Discharge Muffler Discharge Muffler Discharge Muffler Discharge Muffler Discharge Muffler Discharge Muffler Discharge Muffler Discharge Muffler Discharge Disc		Run Capacitor 115/60/1								Not Available				
Page Page		Sound Jacket			92P504A01				92P5	23-01			92P524-01	
PSC Motor 19601		Discharge Muffler					Not Available						36P503B02	
PSC Motor 105601	Σ			Not Available				14P515B01			14P5	16B01	14P5	17B01
PSC Motor 105601	d EC			Not Available								Not Av	ailable	
PSC Motor 105601	spee & Blo	VS ECM Motor 230/60/3			Not Available				14P515B01		14P5 ²	16B01	14P5	17B01
PSC Motor 105601	able S	VS ECM Motor 460/60/3			Not Available				14P515B03		14P5 ²	16B03	14P5	17B03
PSC Motor 105601	Varia	VS ECM Blower Housing		Not Available				53P512B01				53P5	L 15B01	
PSC Motor 25060/1		PSC Motor 115/60/1		14P506-03						Not Available				
PSC Blower & Housing SSPEIT-02 S3P517-02 S3P51	er	PSC Motor 208-230/60/1		14P506-02		14P5	07B01	14P508B01	14P509B01	14P510B01	14P511B01	14P512B01	14P5	14B01
PSC Blower & Housing SSPEIT-02 S3P517-02 S3P51	Blow	PSC Motor 265/60/1		14P506-02		14P5	07B02	14P508B02	14P509B02	14P510B02		Not Av	ailable	
PSC Blower & Housing SSPEIT-02 S3P517-02 S3P51	or &	PSC Motor 230/60/3			Not Available			14P508B01	14P509B01	14P510B01	14P511B01	14P512B01	14P5	14B01
PSC Blower & Housing SSPEIT-02 S3P517-02 S3P51	Mot	PSC Motor 460/60/3						14P508B03	14P509B03	14P510B03	14P511B02	14P512B02	14P5 ⁻	14B02
Some Common Com	PSC	PSC Motor 575/60/3	Not Available							l	14P511B03	14P512B03	14P5 ⁻	14B03
208-230/60/1 Not Available 14533-618 14533-610 14533-610 14533-610 14533-610 14533-610 14533-701 14533-702 14533-703		PSC Blower & Housing						53P512B01			53P5	17-02	53P515B01	
Page Page				Not Available		1485	36-18	14\$536-01	14\$536-02	14\$536-03	14\$537-01	14\$537-02	14\$537-03	14\$537-03
Sophis S	CM			Not Available		14S5	36-19	14\$536-06	14S536-07	14\$536-08	Not Available			
Sophis S	peed E				Not Available			14P536-01	14S536-02	14S536-03	14S537-01	14\$537-02	14S537-03	14S537-03
A Flow of the filter Drier Sape of the filte	5-S Mot	460/60/3			Not Available	ı		14\$536-09 14\$536-10 14\$536-11 14\$537-04			14\$537-05 14\$537-06 14\$537-06			
Coax (Copper) 62P587-01 62P581-01 62P586-01 62P586-01 62P586-01 62P586-01 62P586-01 62P586-01 62P586-01 62P586-01 62P572-01 62P566-01 62P566-01 62P573-01 32P608-13 33P608-13 33P508-04 33P508-05		& Housing		Not Available										ı
Filter Differ September	-L	Air Coil					1					1		
Filter Differ September	on Co	Coax (Copper)	62P587-01	62P591-01	62P586-01	62P586-01	62P586-01	62P586-01	62P572-01	62P5	66-01	62P568-01	62P573-01	62P574-01
Filter Differ September	eratik	TXV		33P605-19			33P605-16		33P6	05-02	33P6	05-10	33P608-10	33P605-13
Filter Differ September	efrig	Reversing Valve	33P502-05	33P502-05	33P502-05		33P5	05-04			33P506-04		33P503-05	33P526-04
Transformer 208-230/60/1 15P501B01 Not Available	œ	Filter Drier					36P50	00B01					36P50	00B02
Transformer 265/60/1 15P507B01 Not Available Transformer 230/60/3 Not Available 15P501B01 Transformer 460/60/3 Not Available 15P505B01 Transformer 575/60/3 Not Available 15P506B01 Phase Guard Not Available 19P541A06		Transformer 115/60/1		15P008B02						Not Available				
Transformer 230/60/3 Not Available 15P501B01 Transformer 460/60/3 Not Available 15P505B01 Transformer 575/60/3 Not Available 15P506B01 Phase Guard Not Available 19P541A06		Transformer 208-230/60/1						15P50	01B01					
Transformer 460/60/3 Not Available 15P505B01 Transformer 575/60/3 Not Available 15P506B01 Phase Guard Not Available 19P541A06	ols	Transformer 265/60/1				15P5	07B01	I				Not Av	ailable	
Transformer 460/60/3 Not Available 15P505B01 Transformer 575/60/3 Not Available 15P506B01 Phase Guard Not Available 19P541A06	Contr	Transformer 230/60/3			Not Available			15P501B01						
Phase Guard Not Available 19P541A06			Not Available						15P505B01					
			Not Available					I				15P50	06B01	
High Pressure Switch High Pressure Switch 35P506B02		Phase Guard			Not Available						19P541A06			
5 Now Pressure Switch 35P506B01	sors & eties	High Pressure Switch						35P50	06B02					
	Sens	Low Pressure Switch						35P50	06B01					

Part numbers subject to change. 8/19/13

Notes

Revision Guide

Pages:	Description:	Date:	Ву:
All	Updated with CuproNickel Water Coil Option	20 May 2014	DS
All	Updated with All-Aluminum Air Coils	09 Oct 2013	DS
All	First Published	08 Apr 2013	DS





Product:

Arbor Base SeriesGeothermal/Water Source Heat Pumps Type:

Size: 0.5-6 Ton

Document Type: Installation Manual Part Number: IM1201AZA Release Date: 05/14